

CALCULATION METHOD FOR THE ANALYSIS AND PREVENTION OF OVERPRESSURE DURING REFILLING OF CRYOGENIC TANKS WITH RUPTURE DISK(S)

AIGA 075/11

GLOBALLY HARMONISED DOCUMENT

Based on CGA P-40 - 2011 3rd edition

Asia Industrial Gases Association

298 Tiong Bahru Road, #20-01 Central Plaza, Singapore 168730 Tel : +65 6276 0160 • Fax : +65 6274 9379 Internet : http://www.asiaiga.org

Doc 075/11 GLOBALLY HARMONISED DOCUMENT



CALCULATION METHOD FOR THE ANALYSIS AND PREVENTION OF OVERPRESSURE DURING REFILLING OF CRYOGENIC TANKS WITH RUPTURE DISK(S)

Disclaimer

All publications of AIGA or bearing AIGA's name contain information, including Codes of Practice, safety procedures and other technical information that were obtained from sources believed by AIGA to be reliable and/ or based on technical information and experience currently available from members of AIGA and others at the date of the publication. As such, we do not make any representation or warranty nor accept any liability as to the accuracy, completeness or correctness of the information contained in these publications.

While AIGA recommends that its members refer to or use its publications, such reference to or use thereof by its members or third parties is purely voluntary and not binding.

AIGA or its members make no guarantee of the results and assume no liability or responsibility in connection with the reference to or use of information or suggestions contained in AIGA's publications.

AIGA has no control whatsoever as regards, performance or non performance, misinterpretation, proper or improper use of any information or suggestions contained in AIGA's publications by any person or entity (including AIGA members) and AIGA expressly disclaims any liability in connection thereto.

AIGA's publications are subject to periodic review and users are cautioned to obtain the latest edition.

Reproduced with permission from, the Compressed Gas Association. All rights reserved.

ASIA INDUSTRIAL GASES ASSOCIATION 298 Tiong Bahru Road #20-01 Central Plaza Singapore 168730 Tel: +65 62760160 Fax: +65 62749379 Internet: http://www.asiaiga.org

- NOTE—Technical changes from the previous edition are underlined.
- NOTE—Appendix A (Normative) is a requirement.
- NOTE—Appendices B, C, D, and E (Informative) are for information only.

	Contents	Page
1	Introduction	1
2	Scope	1
3	Nomenclature	1
4	 Preventing overpressurization	3 3 3
5	Calculations5.1Step 1: Input tank and piping data.5.2Step 2: Determine tank emergency overpressure, P_{eop} .5.3Step 3: Determine maximum frictional pressure loss through the relief system, ΔP_{rel_max} .5.4Step 4: Determine flow resistance of the pressure relief system, K_{rel} .5.5Step 5: Calculate maximum flow rate through the relief system, Q_{rel_max} .5.6Step 6: Determine flow resistance of the truck and tank fill system, K_{truck} and K_{fill} .5.7Step 7: Determine pressure loss through the fill system, ΔP_{fill_line} .5.8Step 8: Determine fill line orifice pressure drop, ΔP_{ori} .5.9Step 9: Determine required fill orifice flow resistance, K_{ori} and size, d_{ori} .	4 5 6 6 7 7 7 7
6	References	8
Tab	ble	
Tat	ble 1—Definition of variables	1
Fig	jure	
Fia	ure 1—System configuration	4
, ig		1
App App	pendices pendix A—Equation sets for the analysis and prevention of overpressure during refilling of cryogenic storage tanks (Normative)	10
Арр Арр	pendix B—Sample calculation 1—onlice is required (informative)	13
Арр	pendix D—Blank calculation forms for the analysis and prevention of overpressure during refilling of cryogenic storage tanks (Informative)	39
Арр	pendix E—Reference data (Informative)	51
Ap	pendices Figures	
Fig Fig Fig Fig	ure B-1—Sample calculation 1—relief line sketch ure B-2—Sample calculation 1—fill line sketch ure C-1—Sample calculation 2—relief line sketch ure C-2—Sample calculation 2—fill line sketch	13 13 26 26
Ар	pendices Tables	
Tat Tat Tat Tat Tat	ble E-1—Fluid density ble E-2—Overall height for typical tanks ble E-3—Pipe and tube inside diameters and inside diameters to the 4th power ble E-4—Typical hydraulic truck pump performance ble E-5—Fill line orifice sizes and flow resistance coefficient referenced to 1.481 in (37.6 mm) internal diameter	51 51 52 53

1 Introduction

Cryogenic transports often use pumping systems that discharge product at pressures exceeding the working pressure of the liquid storage tank being filled. In North America, pumping systems for transferring oxygen, nitrogen, or argon are typically capable of delivering pressures greater than 400 psig (2760 kPa).¹ The cryogenic storage tank being refilled usually has a maximum allowable working pressure (MAWP) that is considerably less than the pump discharge pressure. Depending on the inherent tank design safety factors and the size and flow capacity of the tank pressure relief system, the potential to overpressure the tank during operator-attended manual refill operations exists. <u>CGA P-59</u>, *Prevention of Overpressure During Filling of Cryogenic Vessels*, and <u>EIGA Doc 151/08</u>, AIGA 054/08 *Prevention of excessive pressure during filling of cryogenic vessels*, were written in response to overpressure events that occurred in the compressed gas industry [2,3,4]. <u>CGA P-59</u> <u>EIGA 151/08</u> and <u>AIGA 054/08</u> discuss the requirements necessary to ensure that cryogenic storage tanks are not overpressurized in manual refill operations [2,3,4].

It is the responsibility of each tank owner to complete a technical evaluation of the storage tank fill and relief device piping. This technical evaluation shall be repeated any time a change is made in either the pump flow and pressure capability or the tank fill and relief system flow capacities. The storage tank owner shall ensure that pump operators are properly trained and certified.

2 Scope

This publication provides technical guidance and the complete equation set needed to determine if a particular vessel can or cannot be overpressurized during the refill operation. Acceptable engineering controls for the protection of <u>cryogenic</u> storage tanks <u>and transport tanks with rupture disk(s) as part of the relief system</u> are provided. The application of these engineering controls constitutes a minimum standard.

The calculations in this publication should be used to evaluate each pumping system and <u>cryogenic</u> tank combination in use with oxygen, nitrogen, or argon. It applies to tanks filled either by pump from a cryogenic transport or by a ground-mounted pump. <u>This applies to cryogenic tanks greater than 265 gal (1000 L) water capacity.</u>

3 Nomenclature

Table 1 contains the definitions of the variables used in this standard.

Symbol	Definition	U.S. customary units (abbreviation)	<u>Metric units</u> (abbreviation)
A	Intermediate variable used in calculation of friction factor		
С	Flow coefficient for an orifice		
C _v	Flow coefficient for valves	gallons per minute <u>per psi</u> (gal/min/psi)	
d	Internal line diameter	inches (in)	millimeters (mm)
d _{disc}	Diameter of the rupture disk based on the minimum net flow area as specified by the manufacturer	inches (in)	millimeters (mm)
d _{fill}	Reference internal diameter for the fill line	inches (in)	millimeters (mm)
d ori	Diameter of the fill orifice	inches (in)	millimeters (mm)
d _{rel}	Reference internal diameter for the pressure relief line	inches (in)	millimeters (mm)
f _t	Friction factor (Fanning friction factor used)		

Table 1—Definition of variables

¹ kPa shall indicate gauge pressure unless otherwise noted as (kPa, abs) for absolute pressure or (kPa, differential) for differential pressure. All kPa values are rounded off per CGA P-11, *Metric Practice Guide for the Compressed Gas Industry* [1].

Symbol	Definition	U.S. customary units (abbreviation)	<u>Metric units</u> (abbreviation)
κ	Flow resistance coefficient		
Kb	Flow resistance through a single bend of 90-degrees		
K _{fill}	Flow resistance of the fill line with fill valve in the full open condition. See Figure 1.		
Kori	Flow resistance of the restricting fill line orifice sized so the pressure at the top of the tank during the fill operation cannot exceed P_{eop} . See Figure 1.		
K _R	Certified flow resistance for a rupture disk		
K _{rel}	Flow resistance of the relief system piping from the liquid container up to the rupture disk. See Figure 1. If a diverter valve exists, assume that it is placed in the fully diverted position		
K _{truck}	Flow resistance of the pump to the tee that branches to the fill valves except for the fill orifice. See Figure 1.		
L	Length	feet (ft)	meters (m)
<u>P_{atm}</u>	Atmospheric pressure: 14.7 psia or 1.013 bara	pounds per square inch, absolute (psia)	<u>bar, absolute</u> (bara)
P _{eop}	Tank emergency overpressure. This is the maximum pres- sure that is permissible at the top of the tank under the con- ditions discussed in <u>CGA P-59 EIGA 151/08 and AIGA</u> <u>054/08 [2, 3,4].</u>	pounds per square inch, gauge (psig)	<u>bar, gauge</u> (<u>barg)</u>
P _{mawp}	Tank MAWP per ASME Code or local code equivalent [4].	pounds per square inch, gauge (psig)	<u>bar, gauge</u> (barg)
P _{sup}	Pressure at the inlet of the pump. (Approximately equal to the supply tank pressure).	pounds per square inch, gauge (psig)	<u>bar, gauge</u> (barg)
P _{test}	Test pressure as prescribed by the ASME Code and as re- corded on form U1, U1-A, or R-2 <u>or local code equivalent</u> [4].	pounds per square inch, gauge (psig)	<u>bar, gauge</u> (barg)
Q	Flow rate	gallons per minute (gal/min)	liters per minute (L/min)
Q _{rel_max}	The flow through the relief system so the pressure loss is $\Delta P_{\text{rel_max}}$	gallons per minute (gal/min)	liters per minute (L/min)
r	Radius of a pipe bend	inches (in)	millimeters (mm)
Re	Reynolds number		
V _{liq}	Vertical distance from the bottom of the liquid container to the normal fill level for the tank. See Figure 1.	feet (ft)	meters (m)
V _{pmp}	Vertical distance from the pump to the top of the storage tank liquid container. See Figure 1.	feet (ft)	<u>meters (m)</u>
V _{rel}	Vertical distance from the relief device to the top of the stor- age tank liquid container. See Figure 1.	feet (ft)	<u>meters (m)</u>
V _{tank}	Vertical distance from grade to the top of the storage tank outer container	feet (ft)	<u>meters (m)</u>
ΔP	Pressure loss through pipe and piping components	pounds per square inch (psi)	bar
ΔP_{disc}	Pressure loss through a rupture disk	pounds per square inch (psi)	bar
$\Delta P_{\text{fill_line}}$	Frictional pressure loss through the fill line	pounds per square inch (psi)	bar
ΔP_{ori}	Pressure loss through the fill line orifice	pounds per square inch (psi)	bar

Symbol	Definition	U.S. customary units (abbreviation)	Metric units (abbreviation)
$\varDelta P_{pmp}$	Pump discharge curve for the highest capacity pump ex- pected to fill the tank	pounds per square inch (psi)	<u>bar</u>
∆P _{rel_max}	The maximum frictional pressure loss through the relief system so P_{eop} is not exceeded at the top of the tank	pounds per square inch (psi)	<u>bar</u>
α	Proportionality constant for pipe and tube fitting flow resis- tance used in Appendix A equation (2b)		
β	Diameter ratio (smaller/larger)		
ε	Absolute roughness	inches (in)	millimeters (mm)
μ	Absolute viscosity	centipoise (cp)	Pascal seconds (Pa s)
ρ	Fluid density	pounds (mass) per cubic foot (lbm/ft ³)	<u>kilograms per</u> <u>cubic meter</u> (kg/m ³)
hodes	Density of the highest density lading for which the tank is designed	pounds (mass) per cubic foot (lbm/ft ³)	<u>kilograms per</u> <u>cubic meter</u> (kg/m ³)
θ	Angle of a bend	degrees	degrees

4 Preventing overpressurization

4.1 Methods

<u>CGA P-59</u>, <u>EIGA 151/08 and AIGA 054/08</u> outline a number of methods that protect storage tanks from overpressure during refill [2, 3,4]. One method describes increasing the size of the relief system rupture disk or other component external to the tank if these are found to be restrictive. In some cases due to the internal piping, modifying external components has limited value. When this is the case, installing an external protection device that closes at a prescribed pressure or installing a permanent resistance in the fill piping are possible ways to prevent overpressurization. The solution used shall be inherently reliable, not exclusively dependent upon the driver or operator to take action and shall not introduce other hazards. The use of a liquid relief valve on the tank fill line sized to relieve the full flow capacity of the pump is not recommended because it introduces other hazards associated with large releases of cryogenic fluids to the atmosphere.

4.2 External protection device

A number of external protection devices have been developed specifically to address the issues of overpressure protection during operator-attended refilling. These include control valves installed in the fill line that are actuated by a pressure signal from the vapor space of the storage tank. Closure of the external protection device is accomplished by a pilot system that includes a pressure relief valve or a rupture disk that functions at the appropriate setpoint. The large flow capacity of these valves avoids the operating penalty of the restrictive orifice solution.

4.3 Tank fill and relief system

As illustrated in Figure 1, the tank filling system consists of the cryogenic transport pump and piping; the product transfer hose and connections; and the storage tank, fill piping, and fill line components. The tank relief system consists of the piping from the vapor space of the storage tank, the diverter valve if used, and the tank rupture disk.



NOTES

- 1 K_{truck} and K_{fill} exclude K_{ori}.
- 2 If a diverter valve exists in the relief line, assume it is in the fully diverted position.

Figure 1—System configuration

Many cryogenic storage tanks use relief device lines and components equal to or smaller than the fill lines. Normally a diverter valve, pressure relief valve, and rupture disk are used in a dual relief device assembly to facilitate maintenance. Pressure relief valves and rupture disks are sized for normal operation as well as for exposure of the tank to a fire. Normal operation is often limited to loss of vacuum or uncontrolled pressure building operation. The relief devices may not be sized for the maximum capacity of the refill system. Many older style, lower MAWP storage tanks have a relief capacity between 80 gal/min to 90 gal/min (300 L/min to 340 L/min). Following the calculation methods outlined in Section 5, orifice sizes will typically range from 0.35 in to 0.50 in (10 mm to 13 mm) diameter, effectively reducing the fill rate from a nominal 200 gal/min to as low as 80 gal/min (760 L/min to as low as 300 L/min). Since this clearly is not workable from an operating standpoint, especially with large storage tanks, alternative solutions such as an external protection device should be considered. It is left to the analyst to determine the optimum solution for a particular situation.

5 Calculations

The steps described in 5.1 to 5.9 are used to determine if the relief system incorporated into the <u>cryogenic</u> tank will relieve product at a rate that is greater than the rate at which it can be pumped from the cryogenic <u>source</u>. In this analysis, the tank pressure is allowed to <u>rise above MAWP as prescribed in 5.2</u>. For the purpose of the se calculations, the flow capacity of any pressure relief valve is ignored. The <u>cryogenic</u> tank test pressure specified in the <u>appropriate tank pressure vessel documentation (for</u> *ASME Boiler & Pressure Vessel Code* [ASME Code] test pressure can be found on the pressure vessel U-1, U-1A, or R-2 forms) [5].

The information, equations, and assumptions in 5.1 to 5.9 are used in the equation sets, example worksheets, and blank worksheets in the appendices. Figure 1 depicts the equipment and piping for a typical tank filling operation. References for flow resistances and distances are indicated. Appendix A contains the calculation equation sets. Appendix B presents an example when an orifice is necessary to prevent overpressure during refilling and includes a sketch of the sample relief line and liquid fill line for this example. Appendix C presents an ex-

ample when additional flow restriction in the fill line is not required and includes a sketch of the sample relief line and liquid fill line for this example. Appendix D contains blank worksheets that may be used to complete the analysis described in 5.1 to 5.9. Appendix E contains useful reference data for cryogenic fluids, tanks, pipes, tubes, pumps, and flow orifices that can be helpful when completing an analysis using the blank worksheets in Appendix D.

NOTE—These examples assume sufficient sub-cool is available to prevent two phase flow from occurring in the piping. Consideration for two phase flow prior to the relief device should be considered.

5.1 Step 1: Input tank and piping data

Collect input data specific for the tank being analyzed including the tank owner's name; tank capacity and configuration; manufacturer's serial number; National Board number; product service; whether or not the tank is suitable for argon, nitrogen, and oxygen; tank MAWP and test pressure; and the overall height of the tank. Much of this information is found on the tank dataplate or the manufacturer's <u>documentation such as ASME</u> U-1, U-1A, or R-2 forms.

Inspect the tank relief line from where it exits the tank casing to the discharge of the rupture disk. Enter the different pipe and tube sizes found on the relief line into worksheet D1.

Inspect the tank liquid phase fill line from the fill connection to the point where it enters the casing. Enter the different pipe and tube sizes into worksheet D1.

5.2 Step 2: Determine tank emergency overpressure, *P*_{eop}

Step 2 and worksheet D2 are based on the assumption that the tank design includes a vacuum jacket.

If the tank test pressure is known, then,

Peop is the lesser of:

− <u>P_{eop} = P_{mawp} • 1.5; or</u>

$$- \underline{P_{eop}} = \underline{P_{test}} - \underline{P_{atm}}$$

If the test pressure is unknown, the tank emergency overpressure can be estimated from the following:

U.S. customary units:

$$P_{eop} = 1.1 \left(P_{mawp} + (\rho_{des} - \rho) \bullet \frac{V_{liq}}{144} + P_{atm} \right) - P_{atm}$$

Metric units:

$$P_{eop} = 1.1 \left(P_{mawp} + \frac{(\rho_{des} - \rho) \bullet V_{liq} \bullet 9.81}{100000} + 1 \right) - 1$$

For calculation purposes assume that $V_{liq} = V_{tank} - 3$ ft ($V_{liq} = V_{tank} - 0.91$ m). See Figure 1.

5.3 Step 3: Determine maximum frictional pressure loss through the relief system, ΔP_{rel_max}

The maximum pressure loss allowed through the relief system is equal to the emergency overpressure at the top of the tank plus the liquid head pressure as measured from the top of the tank to the rupture disk inlet.

U.S. customary units:

$$\Delta P_{rel} = P_{eop} + \frac{V_{rel} \bullet \rho}{144}$$

Metric units:

$$\Delta P_{rel_max} = P_{eop} + \frac{V_{rel} \bullet \rho \bullet 9.81}{100000}$$

For calculation purposes assume that $V_{rel} = V_{tank} - 2$ ft $(V_{rel} = V_{tank} - 0.61 \text{ m})$. See Figure 1.

Use worksheet D3.

5.4 Step 4: Determine flow resistance of the pressure relief system, K_{rel}

Analyze the relief line from where it exits the tank casing to the discharge of the rupture disk. Note the different pipe and tube sizes and fittings along the entire length of line. Use actual component sizes and C_v s. Calculate the resistance of each segment using equations (2a) to (2i) in Appendix A or worksheet D4. If a diverter valve exists, assume it is in the fully diverted position. Convert the resistance of each segment to a common diameter using equation (3) in Appendix A. Total all resistances to determine K_{rel} . See Figure 1.

Step 4 and worksheet D4 are based on the following assumptions:

- The calculation reference diameter is 1.481 in <u>(37.6 mm)</u>. All tabulated resistances are converted to this diameter;
- The line friction factor, f_{t_1} is equal to 0.0125;
- The inlet nozzle resistance is based upon a sharp-edged entrance, a 6 in (150 mm) nozzle length, and pipe schedule 40S;
- The internal line bend resistance corresponds to a 90-degree, 8 in (200 mm) radius bend; two 45-degree, 12 in (300 mm) radius bends; and a 1.185 in (30.1 mm) ID line;
- The internal relief line is pipe schedule 5S and is equal in length to the overall height of the tank;
- If the rupture disk certified flow resistance is unknown or cannot be obtained from the manufacturer, use $K_R = 2.4$; and
- The flow capacity of any safety relief valve is neglected.

5.5 Step 5: Calculate maximum flow rate through the relief system, Q_{rel max}

Since the flow resistance and the maximum permissible pressure drop across the relief system is known, use the equation below or worksheet D5 to calculate the maximum flow through the relief system. A factor of 0.9 is used to modify the basic equation (1b) in Appendix A for the calculation of relieving capacity to allow for uncertainties inherent in this method. This complies with the guidelines of the ASME Code, Section VIII, Division 1, paragraph UG-127(b) [4].

U.S. customary units:

$$Q_{rel_max} = 0.9 \bullet \sqrt{\frac{\Delta P_{rel_max} \bullet d_{rel}^{4}}{0.00001799 \bullet K_{rel} \bullet \rho}}$$

Metric units:

$$Q_{rel_max} = 0.9 \bullet 21.07 \sqrt{\frac{\Delta P_{rel_max} \bullet d_{rel}^{4}}{K_{rel} \bullet \rho}}$$

5.6 Step 6: Determine flow resistance of the truck and tank fill system, *K*_{truck} and *K*_{fill}

Analyze the fill line from the cryogenic transport pump discharge, through the fill connection, to the point where the line enters the casing. Note the different pipe and tube sizes and fittings along the entire length of line. Use actual component sizes and C_v s and worksheet D6. Convert the resistance of each component to a common diameter using equation (3) in Appendix A and worksheet D6. Determine a flow resistance for the standard truck components, K_{truck} , and a separate resistance for the tank liquid phase components, K_{fill} . See Figure 1.

Step 6 and worksheet D6 are based on the following assumptions:

- The calculation reference diameter is 1.481 in <u>(37.6 mm)</u>. All tabulated resistances are converted to this diameter.
- The liquid fill line friction factor, f_{t_i} is equal to 0.0138 for an assumed 50% of flow total through the liquid phase fill line. It is assumed that the liquid phase fill valve is fully opened;
- The resistance of standard fill system truck components is equal to 11.519 at a 1.481 in (<u>37.6 mm</u>) reference diameter. These include truck-mounted components, transfer hose, and fill connection indicated in Figure 1;
- The internal liquid line is assumed to be 3 ft (0.91 m) in length and schedule 5S. Internal line bend resistance corresponds to two 90-degree, 10 in (254 mm) radius bends and a 1.770 in (45 mm) ID line; and
- The internal nozzle resistance is based on a sharp-edged exit, a 6 in (152 mm) nozzle length, and pipe schedule 40S.

5.7 Step 7: Determine pressure loss through the fill system, $\Delta P_{fill \ line}$

Calculate the pressure drop across the fill line without an orifice at the flow capacity of the relief system. Use the basic equation (1a) in Appendix A to calculate a separate value for the fill system truck components and the tank liquid phase components. Assume that 50% of the total flow is through the tank liquid phase fill line.

U.S. customary units:

$$\Delta P_{fill_line} = \frac{0.00001799 \bullet K_{truck} \bullet \rho \bullet Q_{rel_max}^2}{d_{fill}^4} + \frac{0.00001799 \bullet K_{fill} \bullet \rho \bullet (Q_{rel_max}/2)^2}{d_{fill}^4}$$

Metric units:

$$\Delta P_{\text{fill_line}} = \frac{K_{\text{truck}} \bullet \rho \bullet Q_{\text{rel_max}}^2}{21.07^2 d_{\text{fill}}^4} + \frac{K_{\text{fill}} \bullet \rho \bullet (Q_{\text{rel_max}}/2)^2}{21.07^2 d_{\text{fill}}^4}$$

Use worksheet D7.

5.8 Step 8: Determine fill line orifice pressure drop, ΔP_{ori}

Subtract the fill line pressure drop, the liquid head from the top of the tank to the pump inlet, and the emergency overpressure at the top of the tank from the sum of the supply pressure and pump pressure rise as shown in the equation below. The pressure rise across the pump, ΔP_{pmp} , is determined by interpolation of the pump curve for the actual lading at the relief system flow capacity. A positive value for ΔP_{ori} indicates that a restricting orifice is needed to match the fill rate to the capacity of the relief system.

U.S. customary units:

$$\Delta P_{ori} = \Delta P_{pmp}(Q_{rel_max}, \rho) + P_{sup} - \Delta P_{fill_line} - V_{pmp} \frac{\rho}{144} - P_{eop}$$

PAGE 8

Metric units:

$$\Delta P_{ori} = \Delta P_{pmp}(Q_{rel_max}, \rho) + P_{sup} - \Delta P_{fill_line} - \frac{(V_{pmp} \bullet \rho \bullet 9.81)}{100000} - P_{eop}$$

Step 8 and worksheet D8 are based upon the following assumptions:

- For calculation purposes assume that $V_{pmp} = V_{tank} 6$ ft ($V_{pmp} = V_{tank} 1.83$ m). See Figure 1;
- The pump performance curve used in the worksheets is a typical pump capacity attainable with some cryogenic transport off-loading systems; and

It is essential that the analyst use the pump curve for the actual pump and components used in a delivery system. Anytime the delivery pump or system characteristics change, this analysis shall be redone to check fill line orifice sizing. This is a major disadvantage of the fill line orifice solution.

5.9 Step 9: Determine required fill orifice flow resistance, *K*_{ori} and size, *d*_{ori}

Using the value for ΔP_{ori} computed above and equation (1c) in Appendix A, compute the flow resistance coefficient required.

Use worksheet D9.

U.S. customary units:

$$\kappa_{ori} = \frac{\Delta P_{ori} \bullet d_{fill}^{4}}{0.00001799 \bullet \rho \bullet Q_{rel_max}^{2}}$$

Metric units:

$$K_{ori} = \frac{21.07^2 \varDelta P_{ori} \bullet d_{fill}^4}{\rho \bullet Q_{rel max}^2}$$

Where:

$$K_{ori} = \frac{1 - \beta^2}{C \bullet \beta^4}$$
 and $\beta = \frac{d_{ori}}{d_{fill}}$

Compute the orifice size by varying d_{ori} until the required resistance is obtained. Alternatively, use worksheet D9 to select an orifice from a list of typical sizes. Select the standard orifice size that has a resistance just greater than K_{ori} .

6 References

Unless otherwise specified, the latest edition shall apply.

[1] CGA P-11, *Metric Practice Guide for the Compressed Gas Industry*, Compressed Gas Association, 4221 Walney Rd., 5th floor, Chantilly, VA 20151. <u>www.cganet.com</u>

[2] <u>CGA P-59</u>, *Prevention of Overpressure During Filling of Cryogenic Vessels*, Compressed Gas Association, 4221 Walney Rd., 5th floor, Chantilly, VA 20151. <u>www.cganet.com</u>

[3] <u>EIGA Doc 151/08</u>, <u>Prevention of excessive pressure during filling of cryogenic vessels</u>, European Industrial Gases Association, Avenue des Arts 3-5, B 1210 Brussels, Belgium. <u>www.eiga.org</u>

[4] AIGA 054/08, <u>Prevention of excessive pressure during filling of cryogenic vessels</u>, Asia Industrial Gases Association. <u>www.asiaiga.org</u>

[5] *ASME Boiler & Pressure Vessel Code*, ASME International, Three Park Ave., New York, NY 10016. www.asme.org

[6] Coker, A.K., "Understanding Two-Phase Flow in Process Piping", *Chemical Engineering Progress*, November 1990, page 60, American Institute of Chemical Engineers, 3 Park Ave., New York, NY 10016. www.aiche.org

[7] Crane Technical Paper No. 410, 1976, *Flow of Fluids through Valves, Fittings, and Pipes*, Crane Valve Group, 2129 3rd Ave. SE, Cullman, AL 35055. <u>www.cranevalve.com</u>

Appendix A—Equation sets for the analysis and prevention of overpressure during refilling of cryogenic storage tanks (Normative)

Equations 1e and 1f in Equation set 1 come from Coker, A. K., "Understanding Two-Phase Flow in Process Piping" [6]. The remaining equations in Equation set 1 and the equations in Equation sets 2 and 3 come from Crane Technical Paper No. 410, *Flow of Fluids through Valves, Fittings, and Pipes* [7].

Equation set 1: Frictional pressure loss through pipe and pipe components

U.S. customary units Metric units Equation

$$\Delta P = \Delta P(Q, K, d, \rho) = \frac{0.00001799 \bullet K \bullet \rho \bullet Q^2}{d^4} \qquad \Delta P = \Delta P(Q, K, d, \rho) = \frac{K \bullet \rho \bullet Q^2}{21.07^2 d^4} \qquad (1a)$$

$$K = K(\Delta P, Q, d, \rho) = \frac{\Delta P \bullet d^4}{0.00001799 \bullet \rho \bullet Q^2} \qquad \qquad K = K(\Delta P, Q, d, \rho) = \frac{21.07^2 \Delta P \bullet d^4}{\rho \bullet Q^2} \qquad (1c)$$

$$f_t = \frac{1}{4 \cdot \log^2 \left(\frac{\varepsilon}{3.7065 \cdot d} - \frac{5.0452 \cdot \log(A)}{Re}\right)}$$
(1e) [6]

$$A = \frac{\left(\frac{\varepsilon}{d}\right)^{1.1098}}{2.8257} + \left(\frac{7.149}{Re}\right)^{.8981}$$
(1f) [6]

$$Re=50.6 \bullet \frac{Q \bullet \rho}{d \bullet \mu} \qquad \qquad Re=0.02122 \bullet \frac{Q \bullet \rho}{d \bullet \mu}$$
(1g)

Equation set 2: Flow resistance of various components

Bends:

 $K = \frac{\theta}{90} \bullet K_b$ Where: $\theta \le 90^\circ$

$$K = \left(\frac{\theta}{90} - 1\right) \bullet \left(.25 \bullet \pi \bullet f_t \bullet \frac{r}{d} + 0.5 \bullet K_b\right) + K_b \qquad \text{Where: } \theta > 90^\circ \tag{2a}$$

Is interpolated from:

$\frac{r}{d}$	1	1.5	2	3	4	6	8	10	12	14	16	20
$\frac{K_b}{f_t}$	20	14	12	12	14	17	24	30	34	38	42	50

Fittings: $K = \alpha \bullet f_t$

Fitting type	α
90-degree elbow	30
45-degree elbow	16
Short radius elbow	40
Tee through run	20
Tee through branch	60
Swing check valve	100

Orifice:

$$Kori = \frac{1 - \beta^2}{C^2 \bullet \beta^4}$$

C may be interpolated from the following table:

β	С
.2	.5975
.3	.6004
.4	.6057
.45	.6111
.5	.6214
.55	.6335
.6	.6510
.65	.6715
.7	.7007
.725	.7182
.75	.7386

(2b)

(2c)

Pipe:

U.S. customary units <u>Metric units</u> Equation $K = f_t \bullet \frac{12 \bullet L}{d} \qquad K = f_t \bullet \frac{10^6 \bullet L}{d} \qquad (2d)$

Sharp contraction:
$$K = \frac{(1 - \beta^2)}{2 \cdot \beta^4}$$
 (for larger diameter) (2e)

Sharp-edged entrance: K = 0.5

Pipe exit: K = 1.0 (2g)

Sharp expansion:
$$K = (1 - \beta^2)^2$$
 (for smaller diameter) (2h)

Valve:

U.S. customary units

Metric units

Equation set 3: Converting to an alternative line size

$$K_1 = K_2 \cdot \left(\frac{d_1}{d_2}\right)^4 \tag{3}$$

Equation set 4: Pump discharge characteristics

$$\Delta P_{pmp} = \Delta P_{pmp}(\rho, \mathbf{Q}) \tag{4}$$

(2f)









Figure B-2—Sample calculation 1—fill line sketch

Z1

Enter the number of tee runs for each diameter. AA1 Enter the number of tee branches for each diameter.

Worksheet B1: Input tank and piping data

	General installation information					
A1	Enter the tank owner's name.					
B1	Enter the tank capacity and configuration.				3 000 gal <u>(11 35</u>	, vertical 5 <u>6 L)</u>
C1	Enter the manufacturer's serial number from the dataplate.					
D1	Enter the National Board number from the dataplate.					
E1	Select the product service.				Oxy	gen
F1	Is this tank designed for argon, nitrogen, and oxygen?				Ye	S
G1	Enter tank MAWP from the dataplate or the manufacturer's U-1	A form.			83 p <u>(5.72 l</u>	sig bar <u>g)</u>
H1	Enter the tank test pressure from the manufacturer's U-1A form	1.			160 j <u>(11 b</u>	osig arg <u>)</u>
11	Enter the overall height of the tank if known or measured.				16 <u>(4.9</u>	ft <u>m)</u>
	Pressure relief line					
Instru of the	ctions: Inspect the relief line from where it exits the tank ca different pipe and tube sizes along the entire length of the l	sing to the d line.	ischarge of t	the ruptur	e disk. Mal	ke a note
		Size 1	Size 2	Size 3	Size 4	Size 5
J1	Enter all external relief line pipe and tube sizes. Start at the tank and finish at the rupture disk exit.	1 in <u>(DN25)</u>	1 in <u>(DN25)</u>	1 in <u>(DN25)</u>	3/4 in <u>(DN20</u>)
K1	Enter the pipe schedule or tube type. Assume the line enter- ing the tank is Sch 5S.	Sch 5S	Туре К	Sch 80S	S Sch 80	S
L1	Enter the total external relief line straight length for each diameter.	6 in <u>(152.4 mm)</u>	120 in (3048 mm)	6 in <u>(152.4 m</u> r	m)	
M1	Enter the number of 90-degree standard elbows for each diameter.		4			
N1	Enter the number of short radius 90-degree elbows (90s) for each diameter.					
01	Enter the number of 45-degree elbows for each diameter.					
P1	Enter the number of tee runs for each diameter.		1			
Q1	Enter the number of tee branches for each diameter.			1		
R1	Enter the diverter valve nominal size.	1 in <u>(DN25)</u>				
S1	Enter the rupture disk diameter based on the minimum net flow area per the manufacturer.	0.750 in <u>(19.1 mm)</u>				
	Liquid phase fill line					
Instru a note	ctions: Inspect the tank liquid phase fill line from the fill cor of the different pipe and tube sizes along the entire length	nnection to tl of the line.	ne point whe	ere it ente	rs the casii	ng. Make
		Size 1	Size 2	Size 3	3 Size 4	Size 5
T1	Enter all external liquid phase fill line pipe and tube sizes. Start at the fill connection and finish at the tank casing.	1-1/2 in <u>(DN40)</u>	1-1/2 in <u>(DN40)</u>			
U1	Enter the pipe schedule or tube type. Assume the line enter- ing the tank is Sch 5S.	Туре К	Sch 5S			
V1	Enter the total liquid phase fill line straight length for each diameter.	66 in <u>(1676 mm)</u>	12 in <u>(305 mm)</u>			
W1	Enter the number of 90-degree standard elbows for each diameter.	4				
X1	Enter the number of short radius elbows for each diameter.					
Y1	Enter the number of 45-degree elbows for each diameter.					

1

AB1	Enter the liquid phase fill valve nominal size.	1-1/2 in <u>(DN40)</u>
AC1	Enter other liquid phase fill line valve nominal size if applica- ble.	None
AD1	Enter the check valve nominal diameter.	1-1/2 in <u>(DN40)</u>

Worksheet B2: Calculate tank emergency overpressure, Peop

A2	Enter the maximum design lading density for the tank from Appendix E Table E-1. Assume argon unless otherwise indicated in F1 Worksheet B1, the manufacturer's dataplate, or U-1A Form.	84.99 lb/ft ³ <u>(1361 kg/m³)</u>
B2	Enter the density from Appendix E Table E-1 for the product in E1 Worksheet B1.	69.57 lb/ft ³ <u>(1114 kg/m³)</u>
C2	Subtract line B2 from line A2. C2 = A2–B2	15.42 lb/ft ³ <u>(247 kg/m³)</u>
D2	Enter the overall height of the tank from Worksheet B1 or Appendix E Table E-2. D2 = I1	16.00 ft <u>(4.88 m)</u>
E2	Determine the vertical distance from the bottom of the liquid container to the normal fill level of the tank in feet. E2 = D2 - 3 ft (Metric units: E2 = D2 - 1 m)	13.00 ft <u>(4.0 m)</u>
F2	Determine available liquid head pressure. F2 = C2 • E2 / 144 (Metric units: F2 = (C2 • E2 • 9.81) / 100000)	1.39 psi <u>(0.1 bar)</u>
Instru	ctions: If the tank test pressure is known, calculate P_{eop} using the preferred method as follows:	
G2	Enter tank test pressure from H1 Worksheet B1. G2 = H1	160.0 psig <u>(11 barg)</u>
H2	Calculate tank emergency overpressure P_{eop} in psig. H2 = G2 – 14.696 (Metric units: H2 = G2 – 1.013)	145.3 psig <u>(10 barg)</u>
Instru	ctions: If the tank test pressure is not known, calculate P_{eop} using the optional method as follow	s:
12	Enter tank MAWP in from G1 Worksheet B1. I2 = G1	83.00 psig <u>(5.7 barg)</u>
J2	Add lines F2, I2, and atmospheric pressure. J2 = F2 + I2 + 14.696 (Metric units: J2 = F2 + I2 + 1.013)	99.09 psig <u>(6.8 barg)</u>
K2	Calculate tank emergency overpressure P_{eop} . K2 = J2 • 1.5 – 14.696 (Metric units: K2 = J2 • 1.5 – 1.013)	133.94 psig <u>(9.2 barg)</u>

Worksheet B3: Calculate the maximum frictional pressure loss through the relief system, ΔP_{rel_max}

A3	Enter B2 from Worksheet B2. A2 = B1	69.57 lb/ft ³ (1114 kg/m ³)
В3	Enter D2 from Worksheet B2. B3 = D2	16.00 ft <u>(4.88 m)</u>
C3	Enter H2 from Worksheet B2 if tank test pressure is known, otherwise enter K2 from Worksheet B2. C3 = H2 or K2	145.3 psig <u>(10 barg)</u>
D3	Determine the vertical distance from the relief device to the top of the storage tank liquid container. D3 = B3 - 2 (Metric units: $D3 = B3 - 0.6$ m)	14.00 ft <u>(4.27 m)</u>
E3	Determine the liquid head in the relief device line. E3 = A3 • D3 / 144 (Metric units: E3 = (A3 • D3 • 9.81) / 100000)	6.76 psi <u>(0.47 bar)</u>
F3	Calculate max pressure loss through relief system, ΔP_{rel_max} . F3 = C3 + E3	152.07 psi <u>(10.49 bar)</u>

Worksheet B4: Calculate the flow resistance of the pressure relief system, K_{rel}

Instr Make	nstructions: Inspect the relief line from where it exits the tank casing to the discharge of the rupture disk. Iake a note of the different pipe and tube sizes along the entire length of the line.							
A4	Calculation reference diameter.				1.481 in <u>(37.6 mm)</u>			
	Relief line internal nozzle							
B4	Enter the relief line schedule 40 inside diameter for the line just B4 = Relief line Sch 40 inside diameter		1.049 <u>(26.6 m</u>	in <u>m)</u>				
C4	Enter pipe entrance flow resistance coefficient.				0.500)		
D4	Determine the flow resistance for the nozzle straight length. D4 = 0.075 / B4 (Metric units: D4 = 1.905/B4)				0.071			
E4	Determine the total flow resistance for the internal nozzle. E4 = C4 + D4				0.571			
F4	Determine the flow resistance conversion factor from size B4 to $F4 = (A4 / B4)^4$	size A4.			3.973	5		
G4	Convert E4 to size A4 equivalent flow resistance. G4 = E4 • F4				2.269	<u>)</u>		
	Relief line internal pipe							
H4	Enter the relief line schedule 5 inside diameter for the line just a H4 = Relief line Sch 5 inside diameter	s it exits the	casing.		1.185 <u>(30.1 m</u>	in <u>m)</u>		
14	Determine the flow resistance for the internal relief line straight I4 = 0.15 • D2 / H4 (Metric units: I4 = 12.5 • D2/H4)	length.			2.025	5		
J4	Determine the flow resistance conversion factor from size H4 to $J4 = (A4 / H4)^4$	size A4.			2.440			
K4	Convert I4 to size A4 equivalent flow resistance. K4 = I4 • J4		4.941					
	Internal line bends							
L4	Enter the flow resistance for the first bend in the internal relief li $L4 = 0.245$	ne.			0.245	5		
M4	Convert L4 to size A4 equivalent flow resistance. M4 = L4 • J4				0.598	8		
N4	Enter the flow resistance for the second bend in the internal reli N4 = 0.189	ef line.			0.189			
04	Convert N4 to size A4 equivalent flow resistance. O4 = N4 • J4				0.461			
P4	Enter the flow resistance for the third bend in the internal relief I P4 = 0.189	ine.			0.189			
Q4	Convert P4 to size A4 equivalent resistance. Q4 = P4 • J4				0.461			
R4	Determine the total flow resistance for all bends in the internal r R4 = M4 + O4 + Q4	elief line.			1.521			
		Size 3	Size 4	Size 5				
	External relief line inside diameters							
S4	Enter all external relief line inside diameters. Start at the tank and finish at the rupture disk. Select inside diameters from Appendix E Table E-3. S4 = All external relief line IDs	1.185 in <u>(30.1 mm)</u>	0.995 in <u>(25.3 mm)</u>	0.957 in <u>(24.3 mm)</u>	0.742 in <u>(18.8 mm)</u>			
T4	Determine the flow resistance conversion factor to size A4 for each line size. T4 = $(A4 / S4)^4$	2.440	4.908	5.736	15.871			

		Size 1	Size 2	Size 3	Size 4	Size 5
	Straight pipe					
U4	Enter the total external relief line straight length for each di- ameter from Worksheet B1. U4 = L1	6 in <u>(152.4 mm)</u>	120 in <u>(3048 mm)</u>	6 in <u>(152.4 mm)</u>		
V4	Determine the flow resistance for each external relief line straight length. V4 = 0.0125 • U4 / S4	0.063	1.508	0.078		
W4	Convert each V4 to size A4 equivalent. W4 = V4 • T4	0.154	7.399	0.449		
X4	Determine the total flow resistance of all straight pipe. X4 = Sum of W4 for all diameters	8.003				
	90-degree standard elbows					
Y4	Enter the number of 90-degree standard elbows for each diameter from Worksheet B1. Y4 = M1		4			
Z4	Determine each 90-degree elbow flow resistance. Z4 = Y4 • 0.375		1.500			
AA4	Convert each Z4 to size A4 equivalent. AA4 = Z4 • T4		7.362			
AB4	Determine the total flow resistance of all 90-degree standard elbows. AB4 = Sum of AA4 for all diameters	7.362				
	Short radius 90s					
AC4	Enter the number of short radius elbows for each diameter from Worksheet B1. AC4 = N1					
AD4	Determine each short radius elbow flow resistance. AD4 = AC4 • 0.500					
AE4	Convert each AD4 to size A4 equivalent. AE4 = AD4 • T4					
AF4	Determine the total flow resistance of all short radius 90s. AF4 = Sum of AE4 for all diameters	0.000				
	45-degree standard elbows					
AG4	Enter the number of 45-degree elbows for each diameter from Worksheet B1. AG4 = O1					
AH4	Determine each 45-degree elbow flow resistance. AH4 = AG4 • 0.200					
AI4	Convert each AH4 to size A4 equivalent. AI4 = AH4 • T4					
AJ4	Determine the total flow resistance of all 45-degree standard elbows.	0.000				
	Tee runs					_
AK4	Enter the number of tee runs for each diameter from Worksheet B1. AK4 = P1		1			
AL4	Determine each tee run flow resistance. AL4 = AK4 • 0.250		0.250			
AM4	Convert each AL4 to size A4 equivalent. AM4 = AL4 • T4		1.227			
AN4	Determine the total flow resistance of all tee runs. AN4 = Sum of AM4 for all diameters	1.227				

		Size 1	Size 2	Size 3	Size 4	Size 5
	Tee branches					
AO4	Enter the number of tee branches for each diameter from Worksheet B1. AO4 = Q1			1		
AP4	Determine each tee branch flow resistance. AP4 = AO4 • 0.750			0.750		
AQ4	Convert each AP4 to size A4 equivalent. AQ4 = AP4 • T4			4.302		
AR4	Determine the total flow resistance of all tee branches. AR4 = Sum of AQ4 for all diameters	4.302				
	Pipe size expansions					
AS4	Enter the smaller inside diameters for all expansions. AS4 = Expander smaller ID					
AT4	Enter the larger inside diameters for all expansions. AT4 = Expander larger ID					
AU4	Determine the square of the small to large diameter ratio for each expansion. AU4 = (AS4 / AT4) ²					
AV4	Determine the resistance coefficient for each expansion. AV4 = $(1 - AU4)^2$					
AW4	Convert each AV4 to size A4 equivalent. AW4 = AV4 • T4					
AX4	Determine the total flow resistance of all pipe size expan- sions. AX4 = Sum of AW4 for all diameters	0.000				
	Pipe size reducers					
AZ4	Enter the smaller inside diameters for all reducers. AZ4 = Reducer smaller ID	0.995 in <u>(25.3 mm)</u>	0.957 in <u>(24.3 mm)</u>	0.742 in <u>(18.8 mm)</u>		
BA4	Determine the small to large diameter ratio for each reducer. BA4 = AZ4 / AY4	0.840	0.962	0.775		
BB4	Determine the resistance coefficient for each reducer. BB4 = $(1 - BA4^2) / (2 \cdot BA4^4)$	0.297	0.044	0.552		
BC4	Convert each BB4 to size A4 equivalent. BC4 = BB4 • T4	0.724	0.215	3.165		
BD4	Determine the total flow resistance of all pipe size reducers. BD4 = Sum of BC4 for all diameters	4.104				
	Diverter valve					
BE4	Enter the diverter valve size from Worksheet B1. BE4 = <u>Internal diameter of R1</u>	1.00 in <u>(25.4 mm)</u>				
BF4	Enter the diverter valve <i>Cv</i> . BF4 = Diverter valve <i>Cv</i>	18.5				
BG4	Determine the diverter valve resistance coefficient. BG4 = 891 • BE4 ⁴ / BF4 ² (Metric: $0.002141 \cdot BE4^4$ / BF4 ²)	2.603				
BH4	Determine the flow resistance conversion factor to size A4 for the diverter valve. BH4 = $(A4 / BE4)^4$	4.811				
BI4	Convert BG4 to size A4 equivalent. BI4 = BG4 • BH4	12.524				

BN4 ate diameter.

BO4 lent.

BP4

BN4 = 1.0

BO4 = BN4 • T4

referenced to size A4, K_{rel}.

Total relief line flow resistance, K_{rel}

AR4 + AX4 + BD4 + BI4 + BM4 + BO4

	Rupture disk	
BJ4	Enter the rupture disk diameter from Worksheet B1.	0.750 in
	BJ4 = S1	<u>(19.1 mm)</u>
BK4	Enter the rupture disk flow resistance coefficient specified by the manufacturer. If unknown, use 2.4. BK4 = 2.4 if unknown	2.400
BL4	Determine the flow resistance conversion factor to size A4 for the rupture disk. BL4 = $(A4 / BJ4)^4$	15.205
BM4	Determine the flow resistance of the rupture disk. BM4 = BK4 • BL4	36.491
	Pipe exit	
	Enter the pipe exit flow resistance coefficient at the appropri-	

98.617

Worksheet B5: Calculate the maximum flow through the relief system, Qrel_max	

Convert the pipe exit resistance coefficient to size A4 equiva-

Determine the flow resistance total for the entire relief line

BP4 = G4 + K4 + R4 + X4 + AB4 + AF4 + AJ4 + AN4 +

A5	Enter B2 from Worksheet B2. A5 = B2	69.57 lb/ft ³ (1114 kg/m ³)
B5	Enter F3 from Worksheet B3. B5 = F3	152.07 psi (10.49 bar)
C5	Enter A4 from Worksheet B4. C5 = A4	1.481 in <u>(37.6 mm)</u>
D5	Enter BP4 from Worksheet B4. D5 = BP4	98.617
E5	Determine C5 to the fourth power from Appendix E Table E-3. E5 = $C5^4$	4.811 in ⁴ (2002421 mm ⁴)
F5	Multiply B5 by E5. F5 = B5 • E5	731.572 <u>(21005385)</u>
G5	Multiply A5 by D5 and 0.000018 (not required for metric). G5 = A5 • D5 • 0.000018 (<u>Metric units: G5 = A5 • D5</u>)	0.123 <u>(109860)</u>
H5	Divide F5 by G5. H5 = F5 / G5	5923.944 <u>(191)</u>
15	Multiply the square root of H5 by 0.9, Q_{rel_max} . I5 = 0.9 • H5 ^{1/2} (Metric units: I5 = 0.9 • 21.07 • H5 ^{1/2})	69.27 gal/min <u>(262 L/min)</u>

1.0

15.871

Worksheet B6: Calculate the Flow Resistance of the Tank Fill System, K_{fill}

Instru a note	Instructions: Inspect the tank liquid phase fill line from the fill connection to the point where it enters the casing. Make a note of the different pipe and tube sizes along the entire length of the line.						
	Fill system standard components						
A6	Enter the truck, hose, and fill connection inside diameter. A6 = Fill system base inside diameter					1.481 i (37.6 m	n m <u>)</u>
B6	Enter the truck, hose, and fill connection flow resistance coefficient. B6 = 11.519					11.519	9
		Size 1	Size 2	Size) 3	Size 4	Size 5
	Liquid phase fill line inside diameters						
C6	Enter all external liquid phase fill line inside diameters. Start after the fill connection and finish at the tank casing. Select inside diameters from Appendix E Table E-3. C6 = All external fill line IDs	1.481 in <u>(37.6 mm)</u>	1.770 in <u>(45.0 mm)</u>				
D6	Determine the flow resistance conversion factor to size A6 for each line size. D6 = $(A6 / C6)^4$	1.000	0.490				
	Straight pipe						
E6	Enter the total liquid phase fill line straight length for each diameter from Worksheet B1. E6 = V1	66 in <u>(1676 mm)</u>	12 in <u>(305 mm)</u>				
F6	Determine the flow resistance for each external fill line straight length. F6 = 0.0138 • E6 / C6	0.615	0.094				
G6	Convert each F6 to size A6 equivalent. G6 = F6 • D6	0.615	0.046				
H6	Determine the total flow resistance of all straight pipe. H6 = Sum of G6 for all diameters	0.661					
	Liquid fill valve(s)	Liquid fill valve	Liquid line valve				
16	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet B1. I6 = AB1 and AC1	<u>1.50 in</u> (38.1 mm)	None				
J6	Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v	39.0					
K6	Determine the liquid fill valve resistance coefficient. $K6 = (891 \cdot 16^4) / J6^2 (Metric units: 0.002141 \cdot 16^4) / J6^2)$	2.966					
L6	Determine the flow resistance conversion factor to size A6 for each valve. L6 = $(A6 / I6)^4$	0.950					
M6	Convert K6 to size A6 equivalent. M6 = K6 • L6	2.818					
N6	Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters	2.818					
	Check valve(s)	-					
O6	Enter the check valve nominal diameter from Worksheet B1. O6 = AD1	<u>1.50 in</u> (38.1 mm)					
P6	Enter the check valve flow resistance coefficient. P6 = 1.380	1.380					
Q6	Determine the flow resistance conversion factor to size A6. Q6 = $(A6 / O6)^4$	0.950					
R6	Convert the check valve resistance coefficient to size A6 equivalent. R6 = P6 • Q6	1.311					

		Size 1	Size 2	Size 3	Size 4	Size 5
	90-degree standard elbows					
S6	Enter the number of 90-degree standard elbows for each diameter from Worksheet B1. S6 = W1	4				
Т6	Determine each 90-degree elbow flow resistance. T6 = S6 • 0.414	1.656				
U6	Convert each T6 to size A6 equivalent. U6 = T6 • D6	1.656				
V6	Determine the total flow resistance of all 90-degree standard elbows. V6 = Sum of U6 for all diameters	1.656				
	Short radius 90s					
W6	Enter the number of short radius elbows for each diameter from Worksheet B1. W6 = X1					
X6	Determine each short radius elbow flow resistance. X6 = W6 • 0.552					
Y6	Convert each W6 to size A6 equivalent. Y6 = X6 • D6					
Z6	Determine the total flow resistance of all short radius 90s. Z6 = Sum of Y6 for all diameters	0.000				
	45-degree standard elbows					
AA6	Enter the number of 45-degree elbows for each diameter from Worksheet B1. AA6 = Y1					
AB6	Determine each 45-degree elbow flow resistance. AB6 = AA6 • 0.221					
AC6	Convert each AA6 to size A6 equivalent. AC6 = AB6 • D6					
AD6	Determine the total flow resistance of all 45-degree standard elbows. AD6 = Sum of AC6 for all diameters	0.000				
	Tee runs					
AE6	Enter the number of tee runs for each diameter from Worksheet B1. AE6 = Z1					
AF6	Determine each tee run flow resistance. AF6 = AE6 • 0.276					
AG6	Convert each AF6 to size A6 equivalent. AG6 = AF6 • D6					
AH6	Determine the total flow resistance of all tee runs. AH6 = Sum of AG6 for all diameters	0.000				
	Tee branches					
AI6	Enter the number of tee branches for each diameter from Worksheet B1. AI6 = AA1	1				
AJ6	Determine each tee branch flow resistance. AJ6 = AI6 • 0.828	0.828				
AK6	Convert each AJ6 to size A6 equivalent. AK6 = AJ6 • D6	0.828				
AL6	Determine the total flow resistance of all tee branches. AL6 = Sum of AK6 for all diameters	0.828				

		Size 1	Size 2	Size 3	Size 4	Size 5
	Pipe size expansions					
AM6	Enter the smaller inside diameters for all expansions. AM6 = Expander smaller ID	1.481 in <u>(37.6 mm)</u>				
AN6	Enter the larger inside diameters for all expansions. AN6 = Expander larger ID	1.770 in <u>(45.0 mm)</u>				
AO6	Determine the square of the small to large diameter ratio for each expansion. AO6 = $(AM6 / AN6)^2$	0.700				
AP6	Determine the resistance coefficient for each expansion. AP6 = $(1 - AO6)^2$	0.090				
AQ6	Convert each AP6 to size A6 equivalent. AQ6 = AP6 • D6	0.090				
AR6	Determine the total flow resistance of all pipe size expansions. AR6 = Sum of AQ6 for all diameters	0.090				
	Pipe size reducers					
AS6	Enter the larger inside diameters for all reducers. AS6 = Reducer larger ID					
AT6	Enter the smaller inside diameters for all reducers. AT6 = Reducer smaller ID					
AU6	Determine the small to large diameter ratio for each reducer. AU6 = AT6 / AS6					
AV6	Determine the resistance coefficient for each reducer. AV6 = $(1 - AU6^2) / (2 \cdot AU6^4)$					
AW6	Convert each AV6 to size A6 equivalent. AW6 = AV6 • D6					
AX6	Determine the total flow resistance of all pipe size reducers. AX6 = Sum of AW6 for all diameters	0.000				
	Fill line internal pipe					
AY6	Enter the liquid phase fill line Sch 5 inside diameter for the line just as it enters the casing. Select inside diameter from Appendix E Table E-3. AY6 = Fill line Sch 5 inside diameter	1.770 in <u>(45 mm)</u>				
AZ6	Enter the length of the tank internal liquid phase fill line. AZ6 = 36 in (Metric units: $AZ6 = 914.4$ mm)	36 in (914 4 mm)				
BA6	Determine the flow resistance for the internal fill line straight length. BA6 = 0.0138 • AZ6 / AY6	0.281				
BB6	Determine the flow resistance conversion factor from size AY6 to size A6. BA6 = (A6 / AY6) ⁴	0.490				
BC6	Convert BA6 to size A6 equivalent flow resistance. BC6 = BA6 • BB6	0.138				
	Internal line bends					
BD6	Enter the flow resistance for the first bend in the internal fill line. BD6 = 0.228	0.228				
BE6	Convert BD6 to size A6 equivalent flow resistance. BE6 = BD6 • BB6	0.112				
BF6	Enter the flow resistance for the second bend in the internal fill line. BF6 = 0.228	0.228				
BG6	Convert BF6 to size A6 equivalent flow resistance. BG6 = BF6 • BB6	0.112				
BH6	Determine the total flow resistance for all bends in the internal fill line. BH6 = BE6 + BG6	0.224				

	Fill line internal nozzle		
B16	Enter the fill line schedule 40 inside diameter for the line just as it enters the casing. BI6 = Fill line Sch 40 inside diameter	1.610 in <u>(40.9 mm)</u>	
BJ6	Enter pipe exit flow resistance coefficient. BJ6 = 1.0	1.000	
BK6	Determine the flow resistance for the nozzle straight length. BK6 = 0.0828 / BI6 (Metric units: BK6 = 2.1163 / BI6)	0.051	
BL6	Determine the total flow resistance for the internal nozzle. BL6 = BJ6 + BK6	1.051	
BM6	Determine the flow resistance conversion factor from size BI6 to size A6. BM6 = (A6 / BI6) ⁴	0.716	
BN6	Convert the internal nozzle resistance coefficient to size A6 equiva- lent. BN6 = BL6 • BM6	0.753	
	Total fill line flow resistance, <i>K</i> _{fill}		
BO6	Determine the flow resistance total for the entire fill line referenced to size A6, <i>K</i> _{fill} . BO6 = H6 +N6 + R6 + V6 + Z6 + AD6 + AH6 + AL6 + AR6 + AX6 + BC6 + BH6 + BN6	8.478	

Worksheet B7: Calculate the pressure loss through the fill system, $\Delta P_{\text{fill_line}}$

	Fill system standard components	
A7	Enter B2 from Worksheet B2. A7 = B2	69.57 lb/ft ³ <u>(1114 kg/m³)</u>
B7	Enter I5 from Worksheet B5. B7 = I5	69.270 gal/min <u>(262 L/min)</u>
C7	Enter A6 from Worksheet B6. C7 = A6	1.481 in <u>(37.6 mm)</u>
D7	Enter B6 from Worksheet B6. D7 = B6	11.519
E7	Enter C7 to the fourth power from Appendix E Table E-3. E7 = $C7^4$	4.811 in ⁴ (2002420 mm ⁴)
F7	Calculate the square of B7. F7 = $B7^2$	4798.395 gal/min ² (68644 L/min ²)
G7	Multiply F7 by A7 and 0.000018 (<u>not required for metric).</u> G7 = F7 • A7 • 0.000018 (<u>Metric units: G7 = F7 • A7</u>)	6.009 <u>(76469416)</u>
H7	Multiply D7 by G7. H7 = D7 • G7	69.216 <u>(880851203)</u>
17	Determine the pressure drop through the standard components. I7 = H7 / E7 (Metric units: I7 = H7 / (E7 • 21.07 ²)	14.39 psi <u>(0.99 bar)</u>
	Fill system variable components	
J7	Enter BO6 from Worksheet B6. J7 = BO6	8.478
K7	Divide F7 by 4. K7 = F7 / 4	1 199.60 gal/min ² (17 166 L/min ²)
L7	Multiply K7 by A7 and 0.000018 (not required for metric). L7 = K7 • A7 • 0.000018 (Metric units: L7 = K7 • A7)	1.502 <u>(19122924)</u>
M7	Multiply J7 by L7. M7 = J7 • L7	12.736 <u>(162124149)</u>
N7	Determine the pressure drop through the variable components. N7 = M7 / E7 (Metric units: N7 = M7 / (E7 \cdot 21.07 ²)	2.65 psi (0.18 bar)
	Fill system total pressure drop <i>ΔP</i> _{fill_line}	
07	Determine the fill system total pressure drop, $\Delta P_{\text{fill_line.}}$ O7 = I7 + N7	17.03 psi <u>(1.17 bar)</u>

Worksheet B8: Calculate the fill line orifice pressure drop, ⊿Pori

	Pump discharge pressure	
A8	Enter I5 from Worksheet B5. A8 = I5	69.270 gal/min (262 L/min)
B8	Enter the product. B8 = E1	Oxygen
C8	For the product in B8, select the value from Appendix E Table E-4 that is just less than the flow in A8. See Table E-4 note. (Convert to liters if appropriate)	60 gal/min <u>(230 L/min)</u>
D8	Select the value from Appendix E Table E-4 for the flow in C8 and the product in B8.	429.60 psi <u>(29.6 bar)</u>
E8	For the product in B8, select the value from Appendix E Table E-4 that is just greater than the flow in A8.	70 gal/min <u>(265 L/min)</u>
F8	Select the value from Appendix E Table E-4 for the flow in E8 and the product in B8. See Table E-4 note.	427.79 psi <u>29.5 bar</u>
G8	Subtract C8 from A8. G8 = A8 – C8	9.27 gal/min <u>(32 L/min)</u>
H8	Subtract C8 from E8. H8 = E8 – C8	10.00 gal/min <u>(35 L/min)</u>
18	Subtract D8 from F8. I8 = F8 – D8	–1.81 psi <u>(–0.1 bar)</u>
J8	Multiply I8 by G8 and divide by H8. J8 = I8 • G8 / H8	–1.68 psi <u>(–0.09 bar)</u>
K8	Determine the pump pressure rise. K8 = D8 + J8	427.92 psi <u>(29.5 bar)</u>
L8	Determine the pump discharge pressure. L8 = K8 + 30 psi (Metric units: L8 = K8 + 2.1 bar)	457.92 psi <u>(31.5 bar)</u>
	Fill line orifice pressure drop, <i>∆P</i> ori	
M8	Enter D2 from Worksheet B2. M8 = D2	16.00 ft <u>(4.88 m)</u>
N8	Determine the vertical distance from the pump to the top of the storage tank inner container. N8 = M8 – 6 ft (Metric units: N8 = M8 – 1.8 m)	10.00 ft <u>(3.05 m)</u>
O8	Enter B2 from Worksheet B2. O8 = B2	69.57 lb/ft ³ <u>(1114 kg/m³)</u>
P8	Determine liquid head pressure based on N8. P8 = N8 • O8 / 144 (Metric units: P8 = (N8 • O8 • 9.81) / 100000)	4.83 psi <u>(0.33 bar)</u>
Q8	Enter J2 from Worksheet B2. Q8 = J2	99.09 psig <u>(6.8 barg)</u>
R8	Enter O7 from Worksheet B7. R8 = O7	17.03 psi <u>(1.17 bar)</u>
S8	Determine the fill line orifice pressure drop, ΔP_{ori} . S8 = L8 – P8 – Q8 – R8	336.97 psi <u>(23.2 bar)</u>

Worksheet B9: Determine the required fill line orifice size, dori

	Orifice flow coefficient, K _{ori}	
A9	Enter E7 from Worksheet B7. A9 = E7	4.811 in ⁴ (2002420 mm ⁴)
B9	Enter S8 from Worksheet B8. B9 = S8	336.97 psi <u>(23.2 bar)</u>
C9	Enter G7 from Worksheet B7. C9 = G7	6.009 <u>(76469416)</u>
D9	Multiply A9 by B9. D9 = A9 • B9 (Metric units: D9 = $21.07^2 \cdot A9 \cdot B9$)	1321.15 <u>(20623968202)</u>
E9	Determine the required flow coefficient for the fill line orifice, K_{ori} . E9 = D9 / C9	269.78
	Fill line orifice diameter	
F9	Select the flow coefficient from Appendix E Table E-5 that is just greater than E9.	295.21
G9	Select the orifice diameter from Appendix E Table E-5 that is in the same row as the flow coeffi- cient in F9.	0.450 in <u>11.4 mm</u>



Appendix C—Sample calculation 2—orifice is not required (Informative)





Figure C-2—Sample calculation 2—fill line sketch

Worksheet C1: Input tank and piping data

	General installation information					
A1	Enter the tank owner's name.					
B1	Enter the tank capacity and configuration.			25 000 gal, horizontal (94 600 L)		zontal
C1	Enter the manufacturer's serial number from the dataplate.					
D1	Enter the National Board number from the dataplate.					
E1	Select the product service.				Nitrogen	
F1	Is this tank designed for argon, nitrogen, and oxygen?				Yes	
G1	Enter tank MAWP from the dataplate or the manufacturer's U-1A forn	٦.		175 psig (12.1 barg)		
H1	Enter the tank test pressure from the manufacturer's U-1A form.			ĺ	Jnknown	
11	Enter the overall height of the tank if known or measured.				15.5 ft (4.72 m)	
	Pressure relief line					
Instru note d	ctions: Inspect the relief line from where it exits the tank casing t of the different pipe and tube sizes along the entire length of the l	o the discha ine.	rge of the ru	ıpture di	sk. Make	a
		Size 1	Size 2	Size 3	Size 4	Size 5
14	Enter all external relief line pipe and tube size. Start at the tank and	1-1/2 in	1 in			
JI	finish at the rupture disk exit.	<u>(DN40)</u>	<u>(DN25)</u>			
K1	Enter the pipe schedule or tube type. Assume the line entering the tank is Sch 5S.	Sch 5S	Sch 5S			
L1	Enter the total external relief line straight length for each diameter.	96 in	186 in			
		<u>(2438 mm)</u>	<u>(4/24 mm)</u>	-		
M1	Enter the number of 90-degree standard elbows for each diameter.	2		-		
N1	Later the number of short radius 90-degree elbows (90s) for each diameter.					
01	Enter the number of 45-degree elbows for each diameter.					
P1	Enter the number of tee runs for each diameter.	1	1			
Q1	Enter the number of tee branches for each diameter.					
R1	Enter the diverter valve nominal size.	1 in <u>(DN25)</u>				
04	Enter the rupture disk diameter based on the minimum net flow area	0.875 in				
51	per the manufacturer.	<u>(22.2 mm)</u>				
	Liquid phase fill line					
Instru	ctions: Inspect the tank liquid phase fill line from the fill connect	ion to the po	int where it e	enters th	ne casing	g. Make
u not		Size 1	Size 2	Size 3	Size 4	Size 5
	Enter all external liquid phase fill line pipe and tube sizes. Start at	1-1/2 in	2 in	0.200	0.20 .	0.20 0
T1	the fill connection and finish at the tank casing.	(DN40)	(DN50)			
U1	Enter the pipe schedule or tube type. Assume the line entering the tank is Sch 5S.	Sch 5S	Sch 5S			
V/1	Enter the total liquid phase fill line straight length for each diameter.	36 in	36 in			
VI		<u>(914 mm)</u>	<u>(914 mm)</u>			
W1	Enter the number of 90-degree standard elbows for each diameter.		2			
X1	Enter the number of short radius elbows for each diameter.	1				
Y1	Enter the number of 45-degree elbows for each diameter.					
Z1	Enter the number of tee runs for each diameter.					
AA1	Enter the number of tee branches for each diameter.	1				
AB1	Enter the liquid phase fill valve nominal size.	2 in (DN50)				
AC1	Enter other liquid phase fill line valve nominal size if applicable.	None				
AD1	Enter the check valve nominal diameter.	None				
		-				

Worksheet C2: Calculate tank emergency overpressure, Peop

A2	Enter the maximum design lading density for the tank from Appendix E Table E-1. Assume argon unless otherwise indicated in F1 Worksheet C1, the manufacturer's dataplate, or U-1A Form.	84.99 lb/ft ³ (1361.4 kg/m ³)
B2	Enter the density in from Appendix E Table E-1 for the product in E1 Worksheet C1.	49.09 lb/ft ³ (786.3 kg/m ³)
C2	Subtract line B2 from line A2. C2 = A2 – B2	35.90 <u>(575.1 kg/m³)</u>
D2	Enter the overall height of the tank from Worksheet C1 or Appendix E Table E-2. D2 = I1	15.50 ft <u>(4.72 m)</u>
E2	Determine the vertical distance from the bottom of the liquid container to the normal fill level of the tank. E2 = D2 - 3 ft (Metric units: E2 = D2 - 1 m)	12.50 ft <u>(2.81 m)</u>
F2	Determine available liquid head pressure. F2 = C2 • E2 / 144 (Metric units: F2 = (C2 • E2 • 9.81) / 100000)	3.12 psi <u>(0.215 bar)</u>
Instruc	ctions: If the tank test pressure is known, calculate P_{eop} using the preferred method as follow	ws:
G2	Enter tank test pressure from H1 Worksheet C1. G2 = H1	Unknown
H2	Calculate the tank emergency overpressure P_{eop} . H2 = G2 – 14.696 psi (Metric units: H2 = G2 – 1 bar)	
Instruc	ctions: If the tank test pressure is not known, calculate P_{eop} using the optional method as fo	llows:
12	Enter tank MAWP from G1 Worksheet C1. I2 = G1	175.00 psi (12.06 bar)
J2	Add lines F2, I2, and atmospheric pressure. J2 = F2 + I2 + 14.696 psi (<u>Metric units: J2 = F2 + I2 + 1.013 bar</u>)	192.81 psig (13.29 barg)
K2	Calculate tank emergency overpressure P_{eop} . K2 = J2 • 1.5 – 14.696 (Metric units: J2 • 1.5 – 1.013)	274.52 psig <u>(18.83 barg)</u>

Worksheet C3: Calculate the maximum frictional pressure loss through the relief system, ∠P_{rel_max}

12	Enter B2 from Worksheet C2.	49.09 lb/ft ³
AS	A3 = B2	<u>(786.3 kg/m³)</u>
В3	Enter D2 from Worksheet C2.	15.50 ft
	B3 = D2	<u>(4.72 m)</u>
C3	Enter H2 from Worksheet C2 if tank test pressure is known, otherwise enter K2 from Worksheet C2. C3 = H2 or K2	274.52 psig <u>(18.83 barg)</u>
D2	Determine the vertical distance from the relief device to the top of the storage tank liquid container.	13.50 ft
03	D3 = B3 – 2 ft (Metric units: D3 = B3 – 0.61 m)	<u>(4.11 m)</u>
E2	Determine the liquid head in the relief device line.	4.60 psi
ES	E3 = A3 • D3 / 144 (Metric units: E3 = (A3 • D3 • 9.81) / 100000)	<u>(0.317 bar)</u>
E2	Calculate max pressure loss through relief system, ΔP_{rel_max} .	279.12 psi
гэ	F3 = C3 + E3	<u>(19.16 bar)</u>

Worksheet C4: Calculate the flow resistance of the pressure relief system, K_{rel}

Instructions: Inspect the relief line from where it exits the tank casing to the discharge of the rupture disk. Make a note of the different pipe and tube sizes along the entire length of the line.					
	Calculation reference diameter				
A4	Calculation reference diameter.	1.481 in <u>(37.6 mm)</u>			
	Relief line internal nozzle				
B4	Enter the relief line schedule 40 inside diameter for the line just as it exits the casing. B4 = Relief line Sch 40 inside diameter	1.610 in (40.9 mm)			
C4	Enter pipe entrance flow resistance coefficient.	0.500			
D4	Determine the flow resistance for the nozzle straight length. D4 = 0.075 / B4 (Metric units: D4 = 1.905 / B4)	0.047			
E4	Determine the total flow resistance for the internal nozzle. E4 = C4 + D4	0.547			
F4	Determine the flow resistance conversion factor from size B4 to size A4. F4 = $(A4 / B4)^4$	<u>0.714</u>			
G4	Convert E4 to size A4 equivalent flow resistance. G4 = E4 • F4	0.391			
	Relief line internal pipe	-			
H4	Enter the relief line schedule 5 inside diameter for the line just as it exits the casing. H4 = Relief line Sch 5 inside diameter	1.770 in <u>(45.0 mm)</u>			
14	Determine the flow resistance for the internal relief line straight length. I4 = 0.15 • D2 / H4 (Metric units: I4 = 12.5 • D2 / H4)	1.314			
J4	Determine the flow resistance conversion factor from size H4 to size A4. $J4 = (A4 / H4)^{4}$	0.490			
K4	Convert I4 to size A4 equivalent flow resistance. K4 = I4 • J4	0.644			
	Internal line bends	•			
L4	Enter the flow resistance for the first bend in the internal relief line. L4 = 0.245	0.245			
M4	Convert L4 to size A4 equivalent flow resistance. M4 = L4 • J4	0.120			
N4	Enter the flow resistance for the second bend in the internal relief line. N4 = 0.189	0.189			
04	Convert N4 to size A4 equivalent flow resistance. O4 = N4 • J4	0.093			
P4	Enter the flow resistance for the third bend in the internal relief line. P4 = 0.189	0.189			
Q4	Convert P4 to size A4 equivalent resistance. Q4 = P4 • J4	0.093			
R4	Determine the total flow resistance for all bends in the internal relief line. R4 = M4 + O4 + Q4	0.305			

		Size 1	Size 2	Size 3	Size 4	Size 5
	External relief line inside diameters	OIZC I	0120 2	0120 3	OIZC 4	0120 0
S4	Enter all external relief line inside diameters Enter all external relief line inside diameters. Start at the tank and finish at the rupture disk. Select inside diameters from Appendix E Table E-3.	1.770 in	1.185 in			
	S4 = All external relief line IDs	<u>(43.0 mm)</u>	<u>(30. i iiiii)</u>			
T4	Determine the flow resistance conversion factor to size A4 for each line size. $T4 = (A4 / S4)^4$	0.490	2.440			
	Straight nine					L
U4	Enter the total external relief line straight length for each diameter from Worksheet C1. U4 = L1	96 in <u>(2438 mm)</u>	186 in <u>(4724 mm)</u>			
V4	Determine the flow resistance for each external relief line straight length. V4 = 0.0125 • U4 / S4	0.678	1.962			
W4	Convert each V4 to size A4 equivalent. W4 = V4 • T4	0.332	4.787			
X4	Determine the total flow resistance of all straight pipe. X4 = Sum of W4 for all diameters	5.119				
	90-degree standard elbows					
Y4	Enter the number of 90-degree standard elbows for each diameter from Worksheet C1. Y4 = M1	2				
Z4	Determine each 90-degree elbow flow resistance. $Z4 = Y4 \cdot 0.375$	0.750				
AA4	Convert each Z4 to size A4 equivalent. AA4 = Z4 • T4	0.368				
AB4	Determine the total flow resistance of all 90-degree standard elbows. AB4 = Sum of AA4 for all diameters	0.368				
	Short radius 90s					
AC4	Enter the number of short radius elbows for each diameter from Worksheet C1.					
AD4	Determine each short radius elbow flow resistance. $AD4 = AC4 \cdot 0.500$					
AE4	Convert each AD4 to size A4 equivalent. AE4 = AD4 • T4					
AF4	Determine the total flow resistance of all short radius 90s. AF4 = Sum of AE4 for all diameters	0.000				
	45-degree standard elbows					
AG4	Enter the number of 45-degree elbows for each diameter from Worksheet C1. AG4 = O1					
AH4	Determine each 45-degree elbow flow resistance. AH4 = AG4 • 0.200					
AI4	Convert each AH4 to size A4 equivalent. AI4 = AH4 • T4					
AJ4	Determine the total flow resistance of all 45-degree standard elbows. AJ4 = Sum of Al4 for all diameters	0.000				

		Size 1	Size 2	Size 3	Size 4	Size 5		
	Tee runs							
AK4	Enter the number of tee runs for each diameter from Worksheet C1. AK4 = P1	1	1					
AL4	Determine each tee run flow resistance. AL4 = AK4 • 0.250	0.250	0.250					
AM4	Convert each AL4 to size A4 equivalent. AM4 = AL4 • T4	0.123	0.610					
AN4	Determine the total flow resistance of all tee runs. AN4 = Sum of AM4 for all diameters	0.732						
	Tee branches							
AO4	Enter the number of tee branches for each diameter from Worksheet C1. AO4 = Q1							
AP4	Determine each tee branch flow resistance. AP4 = AO4 • 0.750							
AQ4	Convert each AP4 to size A4 equivalent. AQ4 = AP4 • T4							
AR4	Determine the total flow resistance of all tee branches. AR4 = Sum of AQ4 for all diameters	0.000						
	Pipe size expansions							
AS4	Enter the smaller inside diameters for all expansions. AS4 = Expander smaller ID							
AT4	Enter the larger inside diameters for all expansions. AT4 = Expander larger ID							
AU4	Determine the square of the small to large diameter ratio for each expansion. AU4 = $(AS4 / AT4)^2$							
AV4	Determine the resistance coefficient for each expansion. AV4 = $(1 - AU4)^2$							
AW4	Convert each AV4 to size A4 equivalent. AW4 = AV4 • T4							
AX4	Determine the total flow resistance of all pipe size expansions. AX4 = Sum of AW4 for all diameters	0.000						
	Pipe size reducers							
AY4	Enter the larger inside diameters for all reducers. AY4 = Reducer larger ID	1.770 in <u>(45.0 mm)</u>						
AZ4	Enter the smaller inside diameters for all reducers. AZ4 = Reducer smaller ID	1.185 in <u>(30.1 mm)</u>						
BA4	Determine the small to large diameter ratio for each reducer. BA4 = AZ4 / AY4	0.669						
BB4	Determine the resistance coefficient for each reducer. BB4 = $(1 - BA4^2) / (2 \cdot BA4^4)$	<u>1.379</u>						
BC4	Convert each BB4 to size A4 equivalent. BC4 = BB4 • T4	<u>0.676</u>						
BD4	Determine the total flow resistance of all pipe size reducers. BD4 = Sum of BC4 for all diameters	<u>0.676</u>						
	Diverter valve							
BE4	Enter the diverter valve size from Worksheet C1. <u>BE4 = Internal diameter of R1</u>	<u>1.00 in</u> (25.4 mm)						
BF4	Enter the diverter valve Cv. BF4 = Diverter valve Cv	24.0						
BG4	Determine the diverter valve resistance coefficient. BG4 = $891 \cdot BE4^4 / BE4^2$ (Metric: BG4 = $0.002141 \cdot BE4^4 / BE4^2$)	1.55						

		Size 1	Size 2	Size 3	Size 4	Size 5		
BH4	Determine the flow resistance conversion factor to size A4 for the diverter valve. BH4 = (A4 / BE4) ⁴	4.81						
BI4	Convert BG4 to size A4 equivalent. BI4 = BG4 • BH4	7.442						
	Rupture disk							
BJ4	Enter the rupture disk diameter from Worksheet C1. BJ4 = S1	0.875 in <u>(22.2 mm)</u>						
BK4	Enter the rupture disk flow resistance coefficient specified by the manufacturer. If unknown, use 2.4. BK4 = 2.4 if unknown	2.650						
BL4	Determine the flow resistance conversion factor to size A4 for the rupture disk. BL4 = $(A4 / BJ4)^4$	8.207						
BM4	Determine the flow resistance of the rupture disk. BM4 = BK4 • BL4	21.749						
	Pipe exit							
BN4	Enter the pipe exit flow resistance coefficient at the appropriate diameter. BN4 = 1.0		1.0					
BO4	Convert the pipe exit resistance coefficient to size A4 equivalent. BO4 = BN4 • T4		2.440					
	Total relief line flow resistance, K _{rel}							
BP4	Determine the flow resistance total for the entire relief line referenced to size A4, K_{rel} . BP4 = G4 + K4 + R4 + X4 + AB4 + AF4 + AJ4 + AN4 + AR4 + AX4 + BD4 + BI4 + BM4 + BO4	39.863						

Worksheet C5: Calculate the maximum flow through the relief system, Q_{rel_max}

۸ <i>Б</i>	Enter B2 from Worksheet C2.	49.09 lb/ft ³
Ab	A5 = B2	<u>(786 kg/m³)</u>
DE	Enter F3 from Worksheet C3.	279.12 psi
Ъ5	B5 = F3	<u>(19.16 bar)</u>
C5	Enter A4 from Worksheet C4	1.481 in
05	C5 = A4	<u>(37.6 mm)</u>
D5	Enter BP4 from Worksheet C4.	30,863
05	D5 = BP4	39.005
5	Determine C5 to the fourth power from Appendix E Table E-3.	4.811 in ⁴
L3	$E5 = C5^4$	<u>(2002420 mm⁴)</u>
E5	Multiply B5 by E5.	1342.822
15	F5 = B5 • E5	<u>(38366367)</u>
G5	Multiply A5 by D5 and 0.000018 (not required for metric).	0.035
05	G5 = A5 • D5 • 0.000018 (<u>Metric units: G5 = A5 • D5)</u>	<u>(31332)</u>
ЦБ	Divide F5 by G5.	38122.359
115	H5 = F5 / G5	<u>(1224.5)</u>
15	Multiply the square root of H5 by 0.9, Q _{rel_max} (and 21.07 for metric).	175.725 gal/min
15	I5 = 0.9 • H5 ^{1/2} (Metric units: I5 = 0.9 • 21.07 • H5 ^{1/2})	<u>(663.57 L/min)</u>

Worksheet C6: Calculate the flow resistance of the tank fill system, K_{fill}

Instru a not	Instructions: Inspect the tank liquid phase fill line from the fill connection to the point where it enters the casing. Make a note of the different pipe and tube sizes along the entire length of the line.							
	Fill system standard components							
	Enter the truck, hose, and fill connection inside diameter.				1.481 ir	ı		
A6	A6 = Fill system base inside diameter				(37.6 mn	n)		
	Enter the truck, hose, and fill connection flow resistance coefficient.							
B6	B6 = 11.519				11.519			
		Size 1	Size 2	Size 3	Size 4	Size 5		
	l iquid phase fill line inside diameters	0.20	0.20 2	0.200	0.20	0.200		
	Enter all external liquid phase fill line inside diameters. Start after the							
	fill connection and finish at the tank casing. Select inside diameters	1.770 in	2.245 in					
C6	from Appendix E Table E-3.	(45.0 mm)	(57.0 mm)					
	C6 = All external fill line IDs	<u>(10.0 mm)</u>	<u>(01.0 mm)</u>					
	Determine the flow resistance conversion factor to size A6 for each							
D6	line size.	0.490	0.189					
	$D6 = (A6 / C6)^4$							
-	Straight pipe							
	Enter the total liquid phase fill line straight length for each diameter							
E6	from Worksheet C1.	36 in	36 in					
	E6 = V1	<u>(914 mm)</u>	<u>(914 mm)</u>					
	Determine the flow resistance for each external fill line straight length.							
F6	F6 = 0.0138 • E6 / C6	0.281	0.221					
	Convert each E6 to size A6 equivalent							
G6	$G6 = F6 \cdot D6$	0.138	0.042					
	Determine the total flow resistance of all straight nine							
H6	H6 = Sum of C6 for all diameters	<u>0.180</u>						
		Liquid	Liquid line	[
	Liquid fill velve/e)							
		fill valve	valve					
	Enter the liquid phase valve(s) diameter(s) based upon nominal	fill valve	valve					
	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from	fill valve	valve					
16	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1.	<u>fill valve</u> <u>2.00 in</u> (50.8 mm)	None					
16	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. I6 = AB1 and AC1	<u>fill valve</u> <u>2.00 in</u> (50.8 mm)	None					
16	Enter the liquid phase valve(s) $\underline{\text{diameter}(s) \text{ based upon}}$ nominal size(s) from Worksheet C1. I6 = AB1 and AC1 Enter the C_v for each liquid phase fill valve.	fill valve <u>2.00 in</u> (50.8 mm)	None					
16 J6	Enter the liquid phase valve(s) diameter(s) based upon nominal size(s) from Worksheet C1. I6 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v	<u>fill valve</u> <u>2.00 in</u> (50.8 mm) 43.0	None					
16 J6	Enter the liquid phase valve(s) diameter(s) based upon nominal size(s) from Worksheet C1. I6 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient.	<u>2.00 in</u> (50.8 mm) 43.0	None					
I6 J6 K6	Enter the liquid phase valve(s) diameter(s) based upon nominal size(s) from Worksheet C1. I6 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • I6 ⁴ / J6 ² (Metric units: K6 = 0.002141 • I6 ⁴ / J6 ²)	<u>2.00 in</u> (50.8 mm) 43.0 <u>7.711</u>	None					
I6 J6 K6	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. 16 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: K6 = 0.002141 • 16 ⁴ / J6 ²) Determine the flow resistance conversion factor to size A6 for each	Liquid fill valve 2.00 in (50.8 mm) 43.0 7.711	None					
I6 J6 K6	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. 16 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: K6 = 0.002141 • 16 ⁴ / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve.	Enquire fill valve 2.00 in (50.8 mm) 43.0 7.711 0.300	None					
I6 J6 K6 L6	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. 16 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: K6 = 0.002141 • 16 ⁴ / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / 16) ⁴	Enquire fill valve 2.00 in (50.8 mm) 43.0 7.711 0.300	None					
I6 J6 K6 L6	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. I6 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: K6 = 0.002141 • 16 ⁴ / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / I6) ⁴	Enquire fill valve 2.00 in (50.8 mm) 43.0 7.711 0.300	None					
I6 J6 K6 L6 M6	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. I6 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (<u>Metric units: K6 = 0.002141 • 16⁴ / J6²</u>) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / I6) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • I 6	Enquis Fill valve 2.00 in (50.8 mm) 43.0 7.711 0.300 2.314	None					
I6 J6 K6 L6 M6	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. 16 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: K6 = 0.002141 • 16 ⁴ / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / 16) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s)	Enquis Fill valve 2.00 in (50.8 mm) 43.0 7.711 0.300 2.314	None					
16 J6 K6 L6 M6	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. 16 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: K6 = 0.002141 • 16 ⁴ / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / 16) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters	Liquid fill valve 2.00 in (50.8 mm) 43.0 7.711 0.300 2.314 2.314	None					
16 J6 K6 L6 M6 N6	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. 16 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: K6 = 0.002141 • 16 ⁴ / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / 16) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters	Liquid fill valve 2.00 in (50.8 mm) 43.0 7.711 0.300 2.314 2.314	None					
16 J6 K6 L6 N6	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. I6 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: K6 = 0.002141 • 16 ⁴ / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / 16) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve(s)	Liquid fill valve 2.00 in (50.8 mm) 43.0 7.711 0.300 2.314 2.314	None					
16 J6 K6 L6 M6 N6 O6	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. I6 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 \cdot 16 ⁴ / J6 ² (Metric units: K6 = 0.002141 \cdot 16 ⁴ / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / I6) ⁴ Convert K6 to size A6 equivalent. M6 = K6 \cdot L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve(s) Enter the check valve nominal diameter from Worksheet C1.	Liquid fill valve 2.00 in (50.8 mm) 43.0 7.711 0.300 2.314 2.314 None	None					
16 J6 K6 L6 M6 N6 O6	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. I6 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • I6 ⁴ / J6 ² (Metric units: K6 = 0.002141 • I6 ⁴ / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / I6) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve (s) Enter the check valve nominal diameter from Worksheet C1. O6 = AD1	Liquid fill valve 2.00 in (50.8 mm) 43.0 7.711 0.300 2.314 2.314 None	None					
16 J6 K6 L6 M6 N6 O6 P6	Enter the liquid fill valve(s) Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. I6 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: K6 = 0.002141 • 16 ⁴ / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / I6) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve(s) Enter the check valve nominal diameter from Worksheet C1. O6 = AD1 Enter the check valve flow resistance coefficient.	Liquid fill valve 2.00 in (50.8 mm) 43.0 7.711 0.300 2.314 2.314 None	None					
16 J6 K6 L6 M6 N6 O6 P6	Enter the liquid fill valve(s) Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. I6 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: K6 = 0.002141 • 16 ⁴ / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / I6) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve(s) Enter the check valve nominal diameter from Worksheet C1. O6 = AD1 Enter the check valve flow resistance coefficient. P6 = 1.380	Liquid fill valve 2.00 in (50.8 mm) 43.0 7.711 0.300 2.314 2.314 None	None					
16 J6 K6 L6 M6 N6 O6 P6 Q6	Enter the liquid fill valve(s) Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. I6 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: K6 = 0.002141 • 16 ⁴ / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / I6) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve(s) Enter the check valve nominal diameter from Worksheet C1. O6 = AD1 Enter the check valve flow resistance coefficient. P6 = 1.380 Determine the flow resistance conversion factor to size A6.	Liquid fill valve 2.00 in (50.8 mm) 43.0 7.711 0.300 2.314 2.314 None	None					
16 J6 K6 L6 M6 N6 O6 P6 Q6	Enter the liquid fill valve(s) Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. I6 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: K6 = 0.002141 • 16 ⁴ / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / I6) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve(s) Enter the check valve nominal diameter from Worksheet C1. O6 = AD1 Enter the check valve flow resistance coefficient. P6 = 1.380 Determine the flow resistance conversion factor to size A6. Q6 = (A6 / O6) ⁴	Liquid fill valve 2.00 in (50.8 mm) 43.0 7.711 0.300 2.314 2.314 None	None					
16 J6 K6 L6 M6 N6 O6 P6 Q6 R6	Enter the liquid fill valve(s) Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1. I6 = AB1 and AC1 Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • I6 ⁴ / J6 ² (Metric units: K6 = 0.002141 • I6 ⁴ / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / I6) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve(s) Enter the check valve nominal diameter from Worksheet C1. O6 = AD1 Enter the check valve flow resistance coefficient. P6 = 1.380 Determine the flow resistance conversion factor to size A6. Q6 = (A6 / O6) ⁴ Convert the check valve resistance coefficient to size A6 equivalent.	Liquid fill valve 2.00 in (50.8 mm) 43.0 7.711 0.300 2.314 2.314 0.300	None					

		Size 1	Size 2	Size 3	Size 4	Size 5
	90-degree standard elbows					
S6	Enter the number of 90-degree standard elbows for each diameter from Worksheet C1.		2			
	S0 = VV Determine each 00 degree allow flow registence					
T6	Determine each 90-degree eibow now resistance. Te = Se $\bullet 0.414$		0.828			
	10 - 30 • 0.414 Convert each T6 to size A6 equivelent					
U6	$LI6 = T6 \cdot D6$		0.157			
	Determine the total flow resistance of all 90-degree standard elbows					
V6	$V_6 = Sum of Ll6 for all diameters$	0.157				
	Short radius 90s					
W6	Enter the number of short radius elbows for each diameter from Work- sheet C1. W6 = X1	1				
X6	Determine each short radius elbow flow resistance.	0.552				
	X6 = W6 • 0.552					
Y6	Convert each W6 to size A6 equivalent. Y6 = X6 \cdot D6	0.271				
Z6	Determine the total flow resistance of all short radius 90s. Z6 = Sum of Y6 for all diameters	0.271		<u> </u>		
	45-degree standard elbows					
	Enter the number of 45-degree elbows for each diameter from					
AA6	Worksheet C1.					
	AA6 = Y1					
AB6	Determine each 45-degree elbow flow resistance.					
	AB6 = AA6 • 0.221					
AC6	Convert each AA6 to size A6 equivalent. AC6 = AB6 \cdot D6					
AD6	Determine the total flow resistance of all 45-degree standard elbows. AD6 = Sum of AC6 for all diameters	0.000		<u> </u>		
	Tee runs					
AE6	Enter the number of tee runs for each diameter from Worksheet C1. AE6 = 71					
	Determine each tee run flow resistance.					
AF6	AF6 = AE6 • 0.276					
AG6	Convert each AF6 to size A6 equivalent. AG6 = AF6 • D6					
AH6	Determine the total flow resistance of all tee runs. AH6 = Sum of AG6 for all diameters	0.000				
	Tee branches					
Al6	Enter the number of tee branches for each diameter from Worksheet C1.	1				
	AI6 = AA1					
AJ6	Determine each tee branch flow resistance.	0.828				
	Convert each A l6 to size A6 equivalent					
AK6	$AK6 = AJ6 \cdot D6$	0.406				
AL6	Determine the total flow resistance of all tee branches. AL6 = Sum of AK6 for all diameters	0.406				

		Size 1	Size 2	Size 3	Size 4	Size 5
	Pipe size expansions					
AMO	Enter the smaller inside diameters for all expansions.	1.770 in				
AIVIO	AM6 = Expander smaller ID	<u>(45.0 mm)</u>				
	Enter the larger inside diameters for all expansions.	2.245 in				
AN6	AN6 = Expander larger ID	<u>(57.0 mm)</u>				
	Determine the square of the small to large diameter ratio for each					
AO6	expansion.	0.622				
	$AO6 = (AM6 / AN6)^2$					
AP6	Determine the resistance coefficient for each expansion.	0 143				
	$AP6 = (1 - AO6)^2$	0.143				
406	Convert each AP6 to size A6 equivalent.	0.070				
7.00	AQ6 = AP6 • D6	0.070				
AR6	Determine the total flow resistance of all pipe size expansions.	0.070				
	AR6 = Sum of AQ6 for all diameters	0.070				
	Pipe size reducers					
156	Enter the larger inside diameters for all reducers.					
A30	AS6 = Reducer larger ID					
AT6	Enter the smaller inside diameters for all reducers.					
AIO	AT6 = Reducer smaller ID					
	Determine the small to large diameter ratio for each reducer.					
A06	AU6 = AT6 / AS6					
AV/6	Determine the resistance coefficient for each reducer.					
AVO	AV6 = (1 – AU6 ²) / (2 • AU6 ⁴)					
A\A/G	Convert each AV6 to size A6 equivalent.					
AVVO	AW6 = AV6 • D6					
AX6	Determine the total flow resistance of all pipe size reducers.	0.000				
ANU	AX6 = Sum of AW6 for all diameters	0.000				
	Fill line internal pipe					
	Enter the liquid phase fill line Sch 5 inside diameter for the line just as					
AY6	it enters the casing. Select inside diameter from	2.245 in				
	Appendix E Table E-3.	<u>(57.0 mm)</u>				
	AY6 = Fill line Sch 5 Inside diameter	00.01				
AZ6	Enter the length of the tank internal liquid phase fill line.	36.0 in				
	AZ6 = 36 in (Metric units: AZ6 = 914.4 mm)	<u>(914.4 mm)</u>				
BA6	Determine the flow resistance for the internal fill line straight length.	0.221				
	$BA6 = 0.0138 \cdot A26 / AY6$					
DDC	Determine the flow resistance conversion factor from size AY6 to size	0.100				
BB0	$BA6 = (A6 / AV6)^4$	0.189				
	Convert BA6 to size A6 equivalent flow resistance					
BC6	$BC6 = BA6 \bullet BB6$	0.042				
	Internal line bends					
	Enter the flow resistance for the first hend in the internal fill line					
BD6	BD6 = 0.228	0.228				
	Convert BD6 to size A6 equivalent flow resistance					
BE6	BE6 = BD6 • BB6	0.043				
	Enter the flow resistance for the second hend in the internal fill line					
BF6	$E_{\text{Intermodely}} = 100 \text{ for the second being in the internal IIII III.e.}$ $BE6 = 0.228$	0.228				
	Convert RE6 to size A6 equivalent flow resistance	╂────┤				
BG6	BC6 = BE6 • BB6	0.043				
	Determine the total flow resistance for all hends in the internal fill line	┼───┤				
BH6	BH6 = BE6 + BG6	0.086				

	Fill line internal nozzle		
B16	Enter the fill line schedule 40 inside diameter for the line just as it en- ters the casing. BI6 = Fill line Sch 40 inside diameter	2.067 in <u>(52.5 mm)</u>	
BJ6	Enter pipe exit flow resistance coefficient. BJ6 = 1.0	1.000	
BK6	Determine the flow resistance for the nozzle straight length. BK6 = 0.0828 / BI6 (Metric units: BK6 = 2.1163 / BI6)	0.040	
BL6	Determine the total flow resistance for the internal nozzle. BL6 = BJ6 + BK6	1.040	
BM6	Determine the flow resistance conversion factor from size BI6 to size A6. BM6 = (A6 / BI6) ⁴	<u>0.263</u>	
BN6	Convert the internal nozzle resistance coefficient to size A6 equivalent. BN6 = BL6 • BM6	0.274	
	Total fill line flow resistance, K _{fill}		
BO6	Determine the flow resistance total for the entire fill line referenced to size A6, <i>K</i> _{fill} . BO6 = H6 +N6 + R6 + V6 + Z6 + AD6 + AH6 + AL6 + AR6 + AX6 + BC6 + BH6 + BN6	<u>3.800</u>	

Worksheet C7: Calculate the pressure loss through the fill system, $\Delta P_{\text{fill_line}}$

	Fill system standard components				
<u>۸</u> 7	Enter B2 from Worksheet C2.	49.09 lb/ft ³			
A/	A7 = B2	<u>(786 kg/m³)</u>			
D7	Enter 15 from Worksheet C5.	175.725 gal/min			
D/	B7 = 15	<u>(663.57 L/min)</u>			
07	Enter A6 from Worksheet C6.	1.481			
07	C7 = A6	<u>(37.6 mm)</u>			
D7	Enter B6 from Worksheet C6.	11 510			
07	D7 = B6	11.518			
E7	Enter C7 to the fourth power from Appendix E Table E-3.	4.811 in⁴			
L/	$E7 = C7^4$	(2002420 mm ⁴)			
E7	Calculate the square of B7.	30879.111 gal/min ²			
17	$F7 = B7^2$	<u>(440325 (L/min²)</u>			
G7	Multiply F7 by A7 and 0.000018 (not required for metric).	27.285			
07	G7 = F7 • A7 • 0.000018 (<u>Metric units: G7 = F7 • A7)</u>	<u>(346095564)</u>			
Н7	Multiply D7 by G7.	314.301			
117	H7 = D7 • G7	<u>(3986674800)</u>			
17	Determine the pressure drop through the standard components.	65.33 psi			
17	I7 = H7 / E7 (Metric units: I7 = H7 / (21.07 ² • E7)	<u>(4.48 bar)</u>			
	Fill system variable components				
17	Enter BO6 from Worksheet C6.	3 803			
57	J7 = BO6	0.000			
K7	Divide F7 by 4.	7719.78 gal/min ²			
107	K7 = F7 / 4	<u>(110224 L/min²)</u>			
17	Multiply K7 by A7 and 0.000018 (not required for metric).	6.821			
Ľ,	L7 = K7 • A7 • 0.000018 (<u>Metric units: L7 = K7 • A7</u>)	<u>(86636064)</u>			
М7	Multiply J7 by L7.	25.95			
1117	M7 = J7 • L7	<u>(329476951)</u>			

N7	Determine the pressure drop through the variable components. N7 = M7 / E7 (Metric units: N7 = M7 / (E7 • 21.07 ²)	5.39 psi <u>(0.37 bar)</u>
	Fill system total pressure drop <i>∆P_{fill_line}</i>	
07	Determine the fill system total pressure drop, ΔP_{fill_line} .	70.73 psig
01	O7 = 17 + N7	<u>(4.86 bar)</u>

Worksheet C8: Calculate the fill line orifice pressure drop, ΔP_{ori}

	Pump discharge pressure	
۸0	Enter 15 from Worksheet C5.	175.725 gal/min
Ao	A8 = 15	<u>(663.57 L/min)</u>
БО	Enter the product.	Nitrogon
БО	B8 = E1	Nillogen
~	For the product in B8, select the value from Appendix E Table E-4 that is just less than the flow in	170 gal/min
0	A8. See note in Table E-4.	<u>(644 L/min)</u>
20	Select the value from Appendix E Table E-4 for the flow in C8 and the product in B8.	233.68 psi
00		<u>(16.11 bar)</u>
EQ	For the product in B8, select the value from Appendix E Table E-4 that is just greater than the flow	180 gal/min
LO	in A8. See note in Table E-4.	<u>(681 L/min)</u>
F8	Select the value from Appendix E Table E-4 for the flow in E8 and the product in B8. See	218.66 psi
10	Table E-4 note.	<u>(15.08 bar)</u>
G8	Subtract C8 from A8.	5.72 gal/min
00	G8 = A8 – C8	<u>(19.57 L/min)</u>
ня	Subtract C8 from E8.	10.00 gal/min
110	H8 = E8 – C8	<u>(37.00 L/min)</u>
18	Subtract D8 from F8.	–15.02 psi
10	18 = F8 – D8	<u>(–1.03 bar)</u>
10	Multiply I8 by G8 and divide by H8.	–8.60 psi
00	J8 = I8 • G8 / H8	<u>(–0.55 bar)</u>
KB	Determine the pump pressure rise.	225.08 psi
NO	K8 = D8 + J8	(<u>15.56 bar)</u>
18	Determine the pump discharge pressure.	255.08 psi
L0	L8 = K8 + 30 psi (Metric units: L8 = K8 + 2.1 bar)	<u>(17.66 bar)</u>
	Fill line orifice pressure drop, <i>∆P_{ori}</i>	
M8	Enter D2 from Worksheet C2.	15.50 ft
IVIO	M8 = D2	<u>(4.72 m)</u>
NR	Determine the vertical distance from the pump to the top of the storage tank inner container.	9.50 ft
NO	N8 = M8 – 6 ft (Metric units: N8 = M8 – 1.8 m)	<u>(2.92 m)</u>
08	Enter B2 from Worksheet C2.	49.09 lb/ft ³
00	O8 = B2	<u>(786.3 kg/m³)</u>
P8	Determine liquid head pressure based on N8.	3.24 psi
10	P8 = N8 • O8 / 144 (<u>Metric units: P8 = (N8 • O8 • 9.81) / 100000</u>)	<u>(0.23 bar)</u>
08	Enter J2 from Worksheet C2.	192.81 psig
QU	Q8 = J2	<u>(13.29 barg)</u>
R8	Enter O7 from Worksheet C7.	70.73 psig
1.0	R8 = 07	<u>(4.86 barg)</u>
58	Determine the fill line orifice pressure drop, ΔP_{ori} .	–11.70 psig
00	S8 = L8 – P8 – Q8 – R8	<u>(-0.72 barg)</u>

Worksheet C9: Determine the required fill line orifice size, *d*ori

	Orifice flow coefficient, K _{ori}	
10	Enter E7 from Worksheet C7.	4.811 in ⁴
A9	A9 = E7	<u>(2002420 mm⁴)</u>
DO	Enter S8 from Worksheet C8.	–11.70 psig
D9	B9 = S8	<u>(-0.72 barg)</u>
<u></u>	Enter G7 from Worksheet C7.	27.285
Ca	C9 = G7	<u>(346095564)</u>
0	Multiply A9 by B9.	-56.29
09	D9 = A9 • B9	<u>(–1441742.4)</u>
ГО	Determine the required flow coefficient for the fill line orifice, K_{ori} .	2
E9	E9 = D9 / C9 (Metric units: E9 = (21.07 ² • D9) / C9)	<u>-2</u>
	Fill line orifice diameter	
F9	Select the flow coefficient from Appendix E Table E-5 that is just greater than E9.	N/A
G9	Select the orifice diameter from Appendix E Table E-5 that is in the same row as the flow coeffi- cient in F9.	None

Appendix D—Blank calculation forms for the analysis and prevention of overpressure during refilling of cryogenic storage tanks (Informative)

Worksheet D1: Input tank and piping data

	General installation information					
A1	Enter the tank owner's name.					
B1	Enter the tank capacity and configuration.					
C1	Enter the manufacturer's serial number from the dataplate.					
D1	Enter the National Board number from the dataplate.					
E1	Select the product service.					
F1	Is this tank designed for argon, nitrogen, and oxygen?					
G1	Enter tank MAWP from the dataplate or the manufacturer's U-1A form					
H1	Enter the tank test pressure from the manufacturer's U-1A form.					
11	Enter the overall height of the tank if known or measured.					
	Pressure relief line					
Instruc Make a	tions: Inspect the relief line from where it exits the tank casing to t note of the different pipe and tube sizes along the entire length of	the discha the line.	rge of the	rupture	disk.	
		Size 1	Size 2	Size 3	Size 4	Size 5
J1	Enter all external relief line pipe and tube size. Start at the tank and finish at the rupture disk exit.					
K1	Enter the pipe schedule or tube type. Assume the line entering the tank is Sch 5S.					
L1	Enter the total external relief line straight length for each diameter.					
M1	Enter the number of 90-degree standard elbows for each diameter.					
N1	Enter the number of short radius 90-degree elbows (90s) for each diameter.					
01	Enter the number of 45-degree elbows for each diameter.					
P1	Enter the number of tee runs for each diameter.					
Q1	Enter the number of tee branches for each diameter.					
R1	Enter the diverter valve nominal size.					
S1	Enter the rupture disk diameter based on the minimum net flow area per the manufacturer.					
	Liquid phase fill line					
Instruc	tions: Inspect the tank liquid phase fill line from the fill connection	n to the po	int where	it enters	the casi	ng. Make
a note	of the different pipe and tube sizes along the entire length of the li	ne.				
		Size 1	Size 2	Size 3	Size 4	Size 5
T1	Enter all external liquid phase fill line pipe and tube sizes. Start at the fill connection and finish at the tank casing.					
U1	Enter the pipe schedule or tube type. Assume the line entering the tank is Sch 5S.					
V1	Enter the total liquid phase fill line straight length for each diameter.					
W1	Enter the number of 90-degree standard elbows for each diameter.					
X1	Enter the number of short radius elbows for each diameter.					
Y1	Enter the number of 45-degree elbows for each diameter.					
Z1	Enter the number of tee runs for each diameter.					
AA1	Enter the number of tee branches for each diameter.					
AB1	Enter the liquid phase fill valve nominal size.					
AC1	Enter other liquid phase fill line valve nominal size if applicable.					
AD1	Enter the check valve nominal diameter.					

Worksheet D2: Calculate tank emergency overpressure, Peop

A2	Enter the maximum design lading density for the tank from Appendix E Table E-1. Assume argon unless otherwise indicated in F1 Worksheet C1, the manufacturer's dataplate, or U-1A Form.	
B2	Enter the density in from Appendix E Table E-1 for the product in E1 Worksheet C1.	
<u></u>	Subtract line B2 from line A2.	
62	C2 = A2 - B2	
D2	Enter the overall height of the tank from Worksheet C1 or Appendix E Table E-2.	
DZ	D2 = I1	
	Determine the vertical distance from the bottom of the liquid container to the normal fill level of	
E2	the tank.	
	E2 = D2 – 3 ft (Metric units: E2 = D2 – 1 m)	
F2	Determine available liquid head pressure.	
12	F2 = C2 • E2 / 144 (Metric F2 = (C2 • E2 • 9.81) / 100000)	
Instruct	ions: If the tank test pressure is known, calculate P_{eop} using the preferred method as follows	:
<u></u>	Enter tank test pressure from H1 Worksheet C1.	
62	G2 = H1	
ЦЭ	Calculate the tank emergency overpressure <i>P</i> _{eop} .	
пг	H2 = G2 – 14.696 psi <u>(Metric units: H2 = G2 – 1.013 bar)</u>	
Instructi	ions: If the tank test pressure is not known, calculate P_{eop} using the optional method as follo	ws:
10	Enter tank MAWP from G1 Worksheet C1.	
12	I2 = G1	
10	Add lines F2, I2, and atmospheric pressure.	
J2	J2 = F2 + I2 + 14.696 psi <u>(Metric units: J2 = F2 + I2 + 1.013 bar)</u>	
140	Calculate tank emergency overpressure Peop.	
K2	K2 = J2 • 1.5 – 14.696 (Metric units: K2 = J2 • 1.5 – 1.013)	

Worksheet D3: Calculate the maximum frictional pressure loss through the relief system, ΔP_{rel_max}

12	Enter B2 from Worksheet C2.	
AS	A3 = B2	
D2	Enter D2 from Worksheet C2.	
- БЭ	B3 = D2	
C3	Enter H2 from Worksheet C2 if tank test pressure is known, otherwise enter K2 from Worksheet C2.	
	C3 = H2 or K2	
50	Determine the vertical distance from the relief device to the top of the storage tank liquid container.	
03	D3 = B3 – 2 ft (<u>Metric units: D3 = B3 – 0.61 m</u>)	
E 3	Determine the liquid head in the relief device line.	
L3	E3 = A3 • D3 / 144 (Metric units: E3 = (A3 • D3 • 9.81) / 100000)	
E2	Calculate max pressure loss through relief system, ΔP_{rel_max} .	
F3	F3 = C3 + E3	

Worksheet D4: Calculate the flow resistance of the pressure relief system, K_{rel}

Instruc Make a	tions: Inspect the relief line from where it exits the tank casing to the note of the different pipe and tube sizes along the entire length of the	e dischai he line.	rge of the	e rupture	disk.	
	Calculation reference diameter					
A4	Calculation reference diameter.					
	Relief line internal nozzle					
	Enter the relief line schedule 40 inside diameter for the line just as it exit	s the cas	ing.			
В4	B4 = Relief line Sch 40 inside diameter					
C4	Enter pipe entrance flow resistance coefficient.					
D 4	Determine the flow resistance for the nozzle straight length.					
D4	D4 = 0.075 / B4 (Metric units: D4 = 1.905 / B4)					
E4	Determine the total flow resistance for the internal nozzle. E4 = C4 + D4					
F4	Determine the flow resistance conversion factor from size B4 to size A4. F4 = (A4 / B4) ⁴					
G4	Convert E4 to size A4 equivalent flow resistance. G4 = E4 • F4					
	Relief line internal pipe					
	Enter the relief line schedule 5 inside diameter for the line just as it exits	the casir	ıg.			
H4	H4 = Relief line Sch 5 inside diameter		-			
14	Determine the flow resistance for the internal relief line straight length.					
14	I4 I4 = 0.15 • D2 / H4 (Metric units: I4 = 12.5 • D2 / H4)					
14	Determine the flow resistance conversion factor from size H4 to size A4.					
J4	$J4 = (A4 / H4)^4$					
K4	Convert I4 to size A4 equivalent flow resistance.					
N 4	K4 = I4 • J4					
	Internal line bends					
1.4	Enter the flow resistance for the first bend in the internal relief line.					
L4	L4 = 0.245					
MA	Convert L4 to size A4 equivalent flow resistance.					
1014	M4 = L4 • J4					
NZ	Enter the flow resistance for the second bend in the internal relief line.					
114	N4 = 0.189					
04	Convert N4 to size A4 equivalent flow resistance.					
04	O4 = N4 • J4					
P4	Enter the flow resistance for the third bend in the internal relief line.					
	P4 = 0.189					
04	Convert P4 to size A4 equivalent resistance.					
<u> </u>	Q4 = P4 • J4					
R4	Determine the total flow resistance for all bends in the internal relief line.					
	R4 = M4 + O4 + Q4					
		Size 1	Size 2	Size 3	Size 4	Size 5
	External relief line inside diameters	r	T	T	r	т
	Enter all external relief line inside diameters. Start at the tank and finish					
54	at the rupture disk. Select inside diameters from Appendix E Table E-3.					
	Determine the flow registence conversion factor to size A4 for each line					
T4	size.					
17	$T4 = (A4 / S4)^4$					

		Size 1	Size 2	Size 3	Size 4	Size 5
	Straight pipe		1			
U4	Enter the total external relief line straight length for each diameter from Worksheet C1. U4 = L1					
V4	Determine the flow resistance for each external relief line straight length. V4 = 0.0125 • U4 / S4					
W4	Convert each V4 to size A4 equivalent. W4 = V4 • T4					
X4	Determine the total flow resistance of all straight pipe. X4 = Sum of W4 for all diameters					
	90-degree standard elbows					
Y4	Enter the number of 90-degree standard elbows for each diameter from Worksheet C1. Y4 = M1					
Z4	Determine each 90-degree elbow flow resistance. Z4 = Y4 • 0.375					
AA4	Convert each Z4 to size A4 equivalent. AA4 = Z4 • T4					
AB4	Determine the total flow resistance of all 90-degree standard elbows. AB4 = Sum of AA4 for all diameters					
	Short radius 90s					
AC4	Enter the number of short radius elbows for each diameter from Worksheet C1. AC4 = N1					
AD4	Determine each short radius elbow flow resistance. AD4 = AC4 • 0.500					
AE4	Convert each AD4 to size A4 equivalent. AE4 = AD4 • T4					
AF4	Determine the total flow resistance of all short radius 90s. AF4 = Sum of AE4 for all diameters					
	45-degree standard elbows					
AG4	Enter the number of 45-degree elbows for each diameter from Worksheet C1. AG4 = O1					
AH4	Determine each 45-degree elbow flow resistance. AH4 = AG4 • 0.200					
Al4	Convert each AH4 to size A4 equivalent. AI4 = AH4 • T4					
AJ4	Determine the total flow resistance of all 45-degree standard elbows. AJ4 = Sum of AI4 for all diameters					
	Tee runs					
AK4	Enter the number of tee runs for each diameter from Worksheet C1. AK4 = P1					
AL4	Determine each tee run flow resistance. AL4 = AK4 • 0.250					
AM4	Convert each AL4 to size A4 equivalent. AM4 = AL4 • T4					
AN4	Determine the total flow resistance of all tee runs. AN4 = Sum of AM4 for all diameters					

		Size 1	Size 2	Size 3	Size 4	Size 5
	Tee branches					
AO4	Enter the number of tee branches for each diameter from Worksheet C1.					
	AO4 = Q1					
	Determine each tee branch flow resistance.					
AP4	AP4 = AO4 • 0.750					
AQ4	Convert each AP4 to size A4 equivalent.					
71021	AQ4 = AP4 • T4					
AR4	Determine the total flow resistance of all tee branches.					
	AR4 = Sum of AQ4 for all diameters					J
	Pipe size expansions					
AS4	Enter the smaller inside diameters for all expansions.					
	AS4 = Expander smaller ID					
AT4	Enter the larger inside diameters for all expansions.					
	AT4 = Expander larger ID					
A114	Determine the square of the small to large diameter ratio for each ex-					
AU4	$\Delta I I A = (\Delta S A / \Delta T A)^2$					
	Determine the resistance coefficient for each expansion					
AV4	$AVA = (1 - AIIA)^2$					
	Convert each AV4 to size A4 equivalent					
AW4	$AW4 = AV4 \cdot T4$					
	Determine the total flow resistance of all pipe size expansions.			1	1	
AX4	AX4 = Sum of AW4 for all diameters					
	Pipe size reducers					
AX/4	Enter the larger inside diameters for all reducers.					
AT4	AY4 = Reducer larger ID					
174	Enter the smaller inside diameters for all reducers.					
724	AZ4 = Reducer smaller ID					
RA4	Determine the small to large diameter ratio for each reducer.					
0/(1	BA4 = AZ4 / AY4					
BB4	Determine the resistance coefficient for each reducer.					
	$BB4 = (1 - BA4^{2}) / (2 \cdot BA4^{4})$	_				
BC4	Convert each BB4 to size A4 equivalent.					
	BC4 = BB4 • 14					
BD4	Determine the total flow resistance of all pipe size reducers.					
	BD4 = Sum of BC4 for all diameters					
	Diverter valve					
BE4	Enter the diverter valve size from worksheet CT.					
	BE4 - <u>Internal diameter of RT</u>		4			
BF4	BE4 = Diverter valve CV					
	Determine the diverter valve resistance coefficient		-			
BG4	$BG4 = 891 \cdot BE4^4 / BE4^2 (Metric: BG4 = 0.002141 \cdot BE4^4 / BE4^2)$					
	Determine the flow resistance conversion factor to size A4 for the		-			
BH4	diverter valve.					
	$BH4 = (A4 / BE4)^4$					
DI 4	Convert BG4 to size A4 equivalent.		1			
В14	BI4 = BG4 • BH4					

		Size 1	Size 2	Size 3	Size 4	Size 5
	Rupture disk					
BJ4	Enter the rupture disk diameter in inches from Worksheet C1. BJ4 = S1					
BK4	Enter the rupture disk flow resistance coefficient specified by the manufacturer. If unknown, use 2.4. BK4 = 2.4 if unknown					
BL4	Determine the flow resistance conversion factor to size A4 for the rupture disk. BL4 = (A4 / BJ4) ⁴					
BM4	Determine the flow resistance of the rupture disk. BM4 = BK4 • BL4					
	Pipe exit					
BN4	Enter the pipe exit flow resistance coefficient at the appropriate diameter. BN4 = 1.0					
BO4	Convert the pipe exit resistance coefficient to size A4 equivalent. BO4 = BN4 • T4					
	Total relief line flow resistance, K _{rel}					
BP4	Determine the flow resistance total for the entire relief line referenced to size A4, K_{rel} . BP4 = G4 + K4 + R4 + X4 + AB4 + AF4 + AJ4 + AN4 + AR4 + AX4 + BD4 + BI4 + BM4 + BO4					

Worksheet D5: Calculate the maximum flow through the relief system, Q_{rel_max}

۸ <i>Б</i>	Enter B2 from Worksheet C2.	
Ab	A5 = B2	
DE	Enter F3 from Worksheet C3.	
60	B5 = F3	
05	Enter A4 from Worksheet C4	
05	C5 = A4	
DE	Enter BP4 from Worksheet C4.	
05	D5 = BP4	
E5	Determine C5 to the fourth power from Appendix E Table E-3.	
	$E5 = C5^4$	
E5	Multiply B5 by E5.	
15	F5 = B5 • E5	
C5	Multiply A5 by D5 and 0.000018 (not required for metric).	
00	G5 = A5 • D5 • 0.000018 (<u>Metric units: G5 = A5 • D5)</u>	
H5	Divide F5 by G5.	
	H5 = F5 / G5	
15	Multiply the square root of H5 by 0.9, Qrel_max (and 21.07 for metric).	
15	$15 = 0.9 \cdot H5^{1/2}$ (Metric units: $15 = 0.9 \cdot 21.07 \cdot H5^{1/2}$)	

Worksheet D6: Calculate the flow resistance of the tank fill system, K_{fill}

a note	tions: Inspect the tank liquid phase fill line from the fill connection to of the different pipe and tube sizes along the entire length of the line.	the point	where it	enters t	he casin	g. Make
	Fill system standard components					
46	Enter the truck, hose, and fill connection inside diameter.					
AU	A6 = Fill system base inside diameter					
De	Enter the truck, hose, and fill connection flow resistance coefficient.					
БО	B6 = 11.519					
		Size 1	Size 2	Size 3	Size 4	Size 5
	Liquid phase fill line inside diameters					
	Enter all external liquid phase fill line inside diameters. Start after the fill					
C6	connection and finish at the tank casing. Select inside diameters from					
	Appendix E Table E-3.					
	C6 = All external fill line IDs					
DC	Determine the flow resistance conversion factor to size A6 for each line					
00	$De = (Ae / Ce)^4$					
	Straight pipe					
	Enter the total liquid phase fill line straight length for each diameter from					
F6	Worksheet C1					
LU	F6 = V1					
	Determine the flow resistance for each external fill line straight length					
F6	$F6 = 0.0138 \cdot F6 / C6$					
	Convert each E6 to size A6 equivalent					
G6	$G6 = F6 \cdot D6$					
	Determine the total flow resistance of all straight pipe					· · · · · · · · · · · · · · · · · · ·
H6	H6 = Sum of G6 for all diameters					
	Liquid fill valve(s)	Liquid fill valve	Liquid line valve			
16	Enter the liquid phase valve(s) <u>diameter(s) based upon</u> nominal size(s) from Worksheet C1.					
	I6 = AB1 and AC1					
16	Enter the O fee each liquid share fill using					
	Enter the C_{ν} for each liquid phase fill value.					
30	Later the C_v for each liquid phase fill value. J6 = Fill value C_v					
50	Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient.					
к6	Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: 0.002141 • 16 ⁴) / J6 ²)					
K6	Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: 0.002141 • 16 ⁴) / J6 ²) Determine the flow resistance conversion factor to size A6 for each					
K6 L6	Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: 0.002141 • 16 ⁴) / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve.					
к6 L6	Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: 0.002141 • 16 ⁴) / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / 16) ⁴					
K6 L6	Enter the C_v for each liquid phase fill valve. $J6 = Fill valve C_v$ Determine the liquid fill valve resistance coefficient. $K6 = 891 \cdot 16^4 / J6^2 (Metric units: 0.002141 \cdot 16^4) / J6^2)$ Determine the flow resistance conversion factor to size A6 for each valve. $L6 = (A6 / 16)^4$ Convert K6 to size A6 equivalent.					
50 K6 L6 M6	Enter the C_v for each liquid phase fill valve. $J6 = Fill valve C_v$ Determine the liquid fill valve resistance coefficient. $K6 = 891 \cdot 16^4 / J6^2 (\underline{Metric units: 0.002141 \cdot 16^4}) / J6^2)$ Determine the flow resistance conversion factor to size A6 for each valve. $L6 = (A6 / 16)^4$ Convert K6 to size A6 equivalent. $M6 = K6 \cdot L6$					
50 K6 L6 M6	Enter the C_v for each liquid phase fill valve. $J6 = Fill valve C_v$ Determine the liquid fill valve resistance coefficient. $K6 = 891 \cdot 16^4 / J6^2 (Metric units: 0.002141 \cdot 16^4) / J6^2)$ Determine the flow resistance conversion factor to size A6 for each valve. $L6 = (A6 / I6)^4$ Convert K6 to size A6 equivalent. $M6 = K6 \cdot L6$ Determine the flow resistance of the liquid fill valve(s).					
K6 L6 M6 N6	Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: 0.002141 • 16 ⁴) / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / 16) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters					
K6 L6 M6 N6	Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: 0.002141 • 16 ⁴) / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / 16) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve(s)					
50 K6 L6 M6 N6	Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: 0.002141 • 16 ⁴) / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / 16) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve(s) Enter the check valve nominal diameter in inches from Worksheet C1.					
30 K6 L6 M6 N6 O6	Enter the C_v for each liquid phase fill valve. J6 = Fill valve C_v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: 0.002141 • 16 ⁴) / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / 16) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve(s) Enter the check valve nominal diameter in inches from Worksheet C1. O6 = AD1					
30 K6 L6 M6 N6 O6 P6	Enter the C _v for each liquid phase fill valve. J6 = Fill valve C _v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: 0.002141 • 16 ⁴) / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / 16) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve(s) Enter the check valve nominal diameter in inches from Worksheet C1. O6 = AD1 Enter the check valve flow resistance coefficient.					
50 K6 L6 M6 N6 O6 P6	Enter the C _v for each liquid phase fill valve. J6 = Fill valve C _v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: 0.002141 • 16 ⁴) / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / 16) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve(s) Enter the check valve nominal diameter in inches from Worksheet C1. O6 = AD1 Enter the check valve flow resistance coefficient. P6 = 1.380					
30 K6 L6 M6 N6 O6 P6 Q6	Enter the C _v for each liquid phase fill valve. J6 = Fill valve C _v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: 0.002141 • 16 ⁴) / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / 16) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve(s) Enter the check valve nominal diameter in inches from Worksheet C1. O6 = AD1 Enter the check valve flow resistance coefficient. P6 = 1.380 Determine the flow resistance conversion factor to size A6.					
30 K6 L6 M6 N6 Q6 Q6	Enter the C _v for each liquid phase fill valve. J6 = Fill valve C _v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: 0.002141 • 16 ⁴) / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / 16) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve(s) Enter the check valve nominal diameter in inches from Worksheet C1. O6 = AD1 Enter the check valve flow resistance coefficient. P6 = 1.380 Determine the flow resistance conversion factor to size A6. Q6 = (A6 / O6) ⁴					
30 K6 L6 M6 N6 O6 P6 Q6 R6	Enter the C _v for each liquid phase fill valve. J6 = Fill valve C _v Determine the liquid fill valve resistance coefficient. K6 = 891 • 16 ⁴ / J6 ² (Metric units: 0.002141 • 16 ⁴) / J6 ²) Determine the flow resistance conversion factor to size A6 for each valve. L6 = (A6 / 16) ⁴ Convert K6 to size A6 equivalent. M6 = K6 • L6 Determine the flow resistance of the liquid fill valve(s). N6 = Sum of M6 for all diameters Check valve(s) Enter the check valve nominal diameter in inches from Worksheet C1. O6 = AD1 Enter the check valve flow resistance coefficient. P6 = 1.380 Determine the flow resistance conversion factor to size A6. Q6 = (A6 / O6) ⁴ Convert the check valve resistance coefficient to size A6 equivalent.					

		Size 1	Size 2	Size 3	Size 4	Size 5
	90-degree standard elbows					
S6	Enter the number of 90-degree standard elbows for each diameter from Worksheet C1.					
	Storming ageh 00 degree albew flow registering		-			
T6	Te = Se • 0.414					
	Convert each T6 to size A6 equivalent					
U6	$U6 = T6 \cdot D6$					
	Determine the total flow resistance of all 90-degree standard elbows					
V6	V6 = Sum of U6 for all diameters					
	Short radius 90s	1				
W6	Enter the number of short radius elbows for each diameter from Work- sheet C1.					
	$VVO - \Lambda I$		-			
X6	$X6 = W6 \cdot 0.552$					
	Convert each W6 to size A6 equivalent					
Y6	$Y6 = X6 \cdot D6$					
70	Determine the total flow resistance of all short radius 90s.					
26	Z6 = Sum of Y6 for all diameters					
	45-degree standard elbows		•			
	Enter the number of 45-degree elbows for each diameter from					
AA6	Worksheet C1.					
	AA6 = Y1					
AB6	Determine each 45-degree elbow flow resistance. AB6 = AA6 • 0.221					
AC6	Convert each AA6 to size A6 equivalent. AC6 = AB6 • D6					
AD6	Determine the total flow resistance of all 45-degree standard elbows. AD6 = Sum of AC6 for all diameters					
	Tee runs					
AE6	Enter the number of tee runs for each diameter from Worksheet C1. AE6 = Z1					
AF6	Determine each tee run flow resistance. AF6 = AE6 • 0.276					
AG6	Convert each AF6 to size A6 equivalent. AG6 = AF6 • D6					
AH6	Determine the total flow resistance of all tee runs. AH6 = Sum of AG6 for all diameters					
	Tee branches					
AI6	Enter the number of tee branches for each diameter from Worksheet C1.					
	AI6 = AA1					
AJ6	Determine each tee branch flow resistance.					
<u> </u>	AJb = AIb + 0.828					
AK6	AK6 = AJ6 • D6					
AL6	Determine the total flow resistance of all tee branches. AL6 = Sum of AK6 for all diameters					

		Size 1	Size 2	Size 3	Size 4	Size 5
	Pipe size expansions					
AM6	Enter the smaller inside diameters for all expansions.					
AIVIO	AM6 = Expander smaller ID					
	Enter the larger inside diameters for all expansions.					
ANO	AN6 = Expander larger ID					
	Determine the square of the small to large diameter ratio for each ex-					
AO6	pansion.					
	$AO6 = (AM6 / AN6)^{-1}$	-				
AP6	Determine the resistance coefficient for each expansion. $ABC = (1 - AOC)^2$					
	AP0 = (1 - AO0)					
AQ6						
	Determine the total flow resistance of all nine size expansions					
AR6	AR6 = Sum of AO6 for all diameters					
	Pine size reducers					
	Enter the larger inside diameters for all reducers					
AS6	AS6 = Reducer larger ID					
	Enter the smaller inside diameters for all reducers.					
AT6	AT6 = Reducer smaller ID					
	Determine the small to large diameter ratio for each reducer.					
AU6	AU6 = AT6 / AS6					
A) (C	Determine the resistance coefficient for each reducer.					
AV6	$AV6 = (1 - AU6^2) / (2 \cdot AU6^4)$					
A\M6	Convert each AV6 to size A6 equivalent.					
700	AW6 = AV6 • D6					
AX6	Determine the total flow resistance of all pipe size reducers.					
7000	AX6 = Sum of AW6 for all diameters					
	Fill line internal pipe					
	Enter the liquid phase fill line Sch 5 inside diameter for the line just as it					
AY6	Appendix E Table E-3.					
	AY6 = Fill line Sch 5 inside diameter					
. = -	Enter the length of the tank internal liquid phase fill line.					
AZ6	AZ6 = 36 in (Metric units: AZ6 = 914.4 mm)					
D 4 0	Determine the flow resistance for the internal fill line straight length.					
BA6	BA6 = 0.0138 • AZ6 / AY6					
	Determine the flow resistance conversion factor from size AY6 to size					
BB6	A6.					
	BA6 = (A6 / AY6) ⁴					
BC6	Convert BA6 to size A6 equivalent flow resistance.					
	$BC6 = BA6 \cdot BB6$					
	Internal line bends	[
BD6						
	BD0 - 0.220					
BE6	BE6 = BD6 • BB6					
	Enter the flow resistance for the second hend in the internal fill line					
BF6	BF6 = 0.228					
	Convert BE6 to size A6 equivalent flow resistance					
BG6	BG6 = BF6 • BB6					
	Determine the total flow resistance for all bends in the internal fill line					
BH6	BH6 = BE6 + BG6					

	Fill line internal nozzle		
B16	Enter the fill line schedule 40 inside diameter for the line just as it enters the casing.		
	BI6 = Fill line Sch 40 inside diameter		
B IG	Enter pipe exit flow resistance coefficient.		
D30	BJ6 = 1.0		
DKG	Determine the flow resistance for the nozzle straight length.		
DRU	BK6 = 0.0828 / BI6 (Metric units: BK6 = 2.1163 / BI6)		
DIG	Determine the total flow resistance for the internal nozzle.		
BLO	BL6 = BJ6 + BK6		
	Determine the flow resistance conversion factor from size BI6 to		
BM6	size A6.		
	$BM6 = (A6 / B16)^4$		
	Convert the internal nozzle resistance coefficient to size A6		
BN6	equivalent.		
	$BN6 = BL6 \cdot BM6$		
	Total fill line flow resistance, <i>K</i> _{fill}		
	Determine the flow resistance total for the entire fill line referenced to		
BO6	size A6, <i>K</i> _{fill} .		
	BO6 = H6 +N6 + R6 + V6 + Z6 + AD6 + AH6 + AL6 + AR6 + AX6 + BC6 + BH6 + BN6		
L			

Worksheet D7: Calculate the pressure loss through the fill system, $\Delta P_{\text{fill_line}}$

	Fill system standard components	
۸7	Enter B2 from Worksheet C2.	
Αı	A7 = B2	
B7	Enter I5 from Worksheet C5.	
ы	B7 = 15	
C7	Enter A6 from Worksheet C6.	
07	C7 = A6	
D7	Enter B6 from Worksheet C6.	
	D7 = B6	
F7	Enter C7 to the fourth power from Appendix E Table E-3.	
	$E7 = C7^4$	
F7	Calculate the square of B7.	
	$F7 = B7^2$	
G7	Multiply F7 by A7 and 0.000018 (not required for metric).	
_	$G7 = F7 \cdot A7 \cdot 0.000018$ (Metric units: $G7 = F7 \cdot A7$)	
H7	Multiply D7 by G7.	
	H7 = D7 • G7	
17	Determine the pressure drop through the standard components.	
	I7 = H7 / E7 (Metric units: I7 = H7 / 21.072 • E7)	
	Fill system variable components	
J7	Enter BO6 from Worksheet C6.	
	J7 = BO6	
K7	Divide F7 by 4.	
L7	Multiply K7 by A7 and 0.000018 (not required for metric).	
	$L7 = K7 \cdot A7 \cdot 0.000018 (Metric units: L7 = K7 \cdot A7)$	
M7		
	$WI = J \cdot L$	

N7	N7 = M7 / E7 (Metric units: N7 = M7 / (E7 • 21.07 ²)	
	Fill system total pressure drop ⊿ <i>P</i> _{fill_line}	
07	Determine the fill system total pressure drop, ΔP_{fill_line} .	
07	O7 = I7 + N7	

Worksheet D8: Calculate the fill line orifice pressure drop, ⊿Pori

	Pump discharge pressure	
<u>۸</u> ۹	Enter I5 from Worksheet C5.	
AU	A8 = 15	
B8	Enter the product.	
00	B8 = E1	
C8	For the product in B8, select the value from Appendix E Table E-4 that is just less than the flow in A8. See note in Table E-4.	
D8	Select the value from Appendix E Table E-4 for the flow in C8 and the product in B8.	
E8	For the product in B8, select the value from Appendix E Table E-4 that is just greater than the flow in A8. See note in Table E-4.	
F8	Select the value from Appendix E Table E-4 for the flow in E8 and the product in B8. See Table E-4 note.	
G8	Subtract C8 from A8. G8 = A8 – C8	
H8	Subtract C8 from E8. H8 = E8 – C8	
10	Subtract D8 from F8.	
18	18 = F8 – D8	
10	Multiply I8 by G8 and divide by H8.	
	J8 = I8 • G8 / H8	
K8	Determine the pump pressure rise.	
	K8 = D8 + J8	
L8	Determine the pump discharge pressure.	
	L8 = K8 + 30 psi (Metric units: L8 = K8 + 2.1 bar)	
	Fill line orifice pressure drop, ΔP_{ori}	
M8	Later D2 from Worksheet C2.	
	NO - D2 Determine the vertical distance from the nump to the top of the storage tank inner container	
N8	N8 = M8 $- 6$ ff (Metric units: N8 = M8 $- 1.8$ m)	
	Enter B2 from Worksheet C2	
08	O8 = B2	
	Determine liquid head pressure based on N8.	
P8	P8 = N8 • O8 / 144 (Metric units: P8 = (N8 • O8 • 9.81) / 100 000)	
08	Enter J2 from Worksheet C2.	
00	Q8 = J2	
R8	Enter O7 from Worksheet C7.	
	R8 = 07	
S8	Determine the fill line orifice pressure drop, ΔP_{ori} .	
	S8 = L8 – P8 – Q8 – R8	

Worksheet D9: Determine the required fill line orifice size, dori

	Orifice flow coefficient, Kori	
A9	Enter E7 from Worksheet C7.	
	A9 = E7	
B9	B9 = S8	
CO	Enter G7 from Worksheet C7.	
Ca	C9 = G7	
٩٩	Multiply A9 by B9.	
03	$D9 = A9 \cdot B9$	
FO	Determine the required flow coefficient for the fill line orifice, K_{ori} .	
L3	E9 = D9 / C9 (Metric units: E9 = (21.07 ² • D9) / C9)	
	Fill line orifice diameter	
F9	Select the flow coefficient from Appendix E Table E-5 that is just greater than E9.	
G9	Select the orifice diameter from Appendix E Table E-5 that is in the same row as the flow coefficient in F9.	

Appendix E—Reference data (Informative)

Table E-1—Fluid density

Dreduct name	Den	sity
Product name	lb/ft ³	kg/m ³
Argon	84.99	1361
Nitrogen	49.09	786.4
Oxygen	69.57	1114

Table E-2—Overall height for typical tanks

Сара	city	Orientation	Н	leight
gal/min	<u>L/min</u>	Orientation	ft	<u>m</u>
500	1 893	Vertical	15.50	4.72
900	3 407	Vertical	15.75	4.80
1 500	5 678	Vertical	15.75	4.80
3 000	11 356	Vertical	16.00	4.88
6 000	22 712	Vertical	25.75	7.85
9 000	34 069	Vertical	27.83	8.48
11 000	41 639	Vertical	31.58	9.63
13 000	49 210	Vertical	36.17	11.02
1 000	3 785	Horizontal	7.58	2.31
1 500	5 678	Horizontal	8.00	2.44
2 000	7 571	Horizontal	8.00	2.44
3 000	11 356	Horizontal	8.42	2.57
6 000	22 712	Horizontal	8.67	2.64
9 000	34 069	Horizontal	10.92	3.33
11 000	41 639	Horizontal	11.67	3.56
13 000	49 210	Horizontal	11.67	3.56
15 000	56 781	Horizontal	11.67	3.56
20 000	75 708	Horizontal	11.67	3.56
25 000	94 635	Horizontal	12.17	3.71
30 000	113 562	Horizontal	12.33	3.76
35 000	132 489	Horizontal	12.33	3.76
40 000	151 416	Horizontal	12.33	3.76
50 000	189 270	Horizontal	12.33	3.76
55 000	208 197	Horizontal	13.33	4.06
65 000	246 051	Horizontal	13.33	4.06
90 000	340 686	Horizontal	13.50	4.11

0:	Inside diameter					
Size	in	mm	in⁴	<u>mm</u> ⁴		
1/2 in Type K	0.527	13.4	0.077	32105		
1/2 in Type L	0.545	13.8	0.088	36722		
1/2 in Sch 5S	0.710	18.0	0.254	105771		
1/2 in Sch 10S	0.674	17.1	0.206	85896		
1/2 in Sch 40S	0.622	15.8	0.150	62301		
1/2 in Sch 80S	0.546	13.9	0.089	36992		
5/8 in Type K	0.652	16.6	0.181	75219		
5/8 in Type L	0.666	16.9	0.197	81890		
3/4 in Type K	0.745	18.9	0.308	128221		
3/4 in Type L	0.785	19.9	0.380	158057		
3/4 in Sch 5S	0.920	23.4	0.716	298185		
3/4 in Sch 10S	0.884	22.5	0.611	254181		
3/4 in Sch 40S	0.824	20.9	0.461	191886		
3/4 in Sch 80S	0.742	18.8	0.303	126168		
1 in Type K	0.995	25.3	0.980	407969		
1 in Type L	1.025	26.0	1.104	459442		
1 in Sch 5S	1.185	30.1	1.972	820745		
1 in Sch 10S	1.097	27.9	1.448	602784		
1 in Sch 40S	1.049	26.6	1.211	504007		
1 in Sch 80S	0.957	24.3	0.839	349126		
1-1/4 in Type K	1.245	31.6	2.403	1000028		
1-1/4 in Type L	1.265	32.1	2.561	1065852		
1-1/2 in Type K	1.481	37.6	4.811	2002420		
1-1/2 in Type L	1.505	38.2	5.130	2135408		
1-1/2 in Sch 5S	1.770	45.0	9.815	4085337		
1-1/2 in Sch 10S	1.682	42.7	8.004	3331492		
1-1/2 in Sch 40S	1.610	40.9	6.719	2796652		
1-1/2 in Sch 80S	1.500	38.1	5.063	2107172		
2 in Type K	1.959	49.8	14.728	6130171		
2 in Type L	1.985	50.4	15.525	6462148		
2 in Sch 5S	2.245	57.0	25.402	10573049		
2 in Sch 10S	2.157	54.8	21.647	9010221		
2 in Sch 40S	2.067	52.5	18.254	7597956		
2 in Sch 80S	1.939	49.3	14.136	5883640		
2-1/2 in Type K	2.435	61.8	35.156	14632911		
2-1/2 in Type L	2.465	62.6	36.921	15367477		
2-1/2 in Sch 5S	2.709	68.8	53.856	22416659		
2-1/2 in Sch 10S	2.635	66.9	48.208	20065840		
2-1/2 in Sch 40S	2.469	62.7	37.161	15467468		
2-1/2 in Sch 80S	2.323	59.0	29.120	12120812		
3 in Type K	2.907	73.8	71.413	29724530		
3 in Type L	2.945	74.8	75.221	31309495		
3 in Sch 5S	3.334	84.7	123.556	51427717		
3 in Sch 10S	3.260	82.8	112.946	47011625		
3 in Sch 40S	3.068	77.9	88.597	36877060		
3 in Sch 80S	2.900	73.7	70.728	29439258		

Table E-3—Pipe and tube inside diameters and inside diameters to the 4th power

Flow		Pressure rise across pump					
		Arg	Argon		Nitrogen		gen
gal/min	<u>L/min</u>	psi	<u>bar</u>	psi	<u>bar</u>	psi	bar
50	189	426.02	29.37	368.00	25.37	431.68	29.76
60	227	423.86	29.22	367.76	25.36	429.60	29.62
70	265	422.04	29.10	366.14	25.24	427.79	29.50
80	303	420.11	28.97	364.86	25.16	426.13	29.38
90	341	409.68	28.25	363.58	25.07	423.49	29.20
100	379	399.25	27.53	358.37	24.71	414.01	28.54
110	416	386.63	26.66	340.62	23.48	404.52	27.89
120	454	372.79	25.70	322.88	22.26	393.52	27.13
130	492	357.14	24.62	302.88	20.88	380.93	26.26
140	530	337.66	23.28	282.18	19.46	368.34	25.40
150	568	318.17	21.94	264.40	18.23	350.36	24.16
160	606	298.15	20.56	249.04	17.17	331.86	22.88
170	644	276.49	19.06	233.68	16.11	313.36	21.61
180	681			218.66	15.08	294.19	20.28
190	719			204.63	14.11	274.45	18.92

NOTE—The analyst is responsible for verifying pump performance for the actual operation being analyzed.

Table E-5—Fill line orifice sizes and flow resistance coefficient referenced to 1.481 in (37.6 mm) internal diameter

Orifice size	Flow resistance, <i>K</i> _{ori}	Fill orifice diameter, dori	
		in	<u>mm</u>
Size A	1.32	1.200	30.5
Size B	2.76	1.100	27.9
Size C	5.56	1.000	25.4
Size D	10.81	0.900	22.9
Size E	20.88	0.800	20.3
Size F	29.13	0.750	19.1
Size G	41.04	0.700	17.8
Size H	58.50	0.650	16.5
Size I	84.42	0.600	15.2
Size J	124.16	0.550	14.0
Size K	187.94	0.500	12.7
Size L	295.21	0.450	11.4
Size M	484.68	0.400	10.2
Size N	844.86	0.350	8.9