



POSITION PAPER

Position Paper PP-08-2024

INSPECTION REQUIREMENTS OF AIR SEPARATION UNIT COLDBOX INTERNAL COMPONENTS

As part of a programme of harmonisation of industry standards, the Asia Industrial Gases Association, (AIGA) has published PP-08-2024, Inspection Requirements of Air Separation Unit Coldbox Internal Components, jointly produced by members of the International Harmonisation Council and originally published by the Compressed Gas Association as CGA PS-72, Inspection Requirements of Air Separation Unit Coldbox Internal Components. This publication is intended as an international harmonised standard for the worldwide use and application of all members of the Asia Industrial Gases Association (AIGA), Compressed Gas Association (CGA), European Industrial Gases Association, and Japan Industrial and Medical Gases Association (JIMGA). Each association's technical content is identical, except for regional regulatory requirements and minor changes in formatting and spelling.

Question

Should the internal components of an air separation unit (ASU) coldbox be subjected to periodic inspection?

Answer

The Asia Industrial Gases Association *does not recommend* that the internal components of an ASU coldbox be subjected to periodic inspections.

Reasons

An ASU coldbox is the cylindrical or rectangular metal enclosure surrounding the cryogenic equipment (internal components) such as distillation columns, exchangers, separators, vessels, associated piping, instrumentation with an annular space that is insulated and purged with dry, clean, noncorrosive gas or kept under vacuum.

Based on more than 60 years of industry operating experience, the industrial gases industry does not carry out periodic inspections of cryogenic equipment within an ASU coldbox for the following reasons:

- Cryogenic plants are constructed from materials that have low corrosion potential. These materials retain their corrosion resistance at temperatures lower than ambient and experience shows that corrosion at cryogenic temperatures is negligible;
- Process fluids are dry, clean, and noncorrosive;
- The ASU coldbox annular space is purged with dry, clean, and noncorrosive gas or kept under vacuum, which minimizes the risk of corrosion;
- Limited presence of the traditional failure mechanisms for such equipment—namely erosion and fatigue due to the external cryogenic ASU coldbox enclosure;
- Design and construction are carried out to well established and internationally recognized codes and standards. Design takes into account pressures, loadings, temperature changes, and movements expected during normal operation, startup, and shut-down;
- Operating mode of a cryogenic ASU is generally steady state with few pressure and temperature variations;
- Materials used in the construction of ASU coldbox internal components, typically austenitic stainless steel and aluminum, have significantly enhanced yield and ultimate tensile strengths at cryogenic operating temperatures; and

- Materials used in the construction of ASU coldbox internal components have high fracture toughness characteristics. The critical defect size for the initiation of an unstable fracture can allow a defect to be detected from an increase in the ASU coldbox pressure or from the presence of cold patches well before the critical defect size is reached.

Periodic inspection and maintenance of the ASU coldbox enclosure are used to ensure its integrity (for example, tightness, purge gas, perlite level, vacuum, absence of embrittlement and corrosion of the carbon steel structure, icing). These inspections are intended to confirm that the environment within the ASU coldbox is dry and inert, and that there are no indications of cryogenic and/or pressure leaks.

The ASU coldbox enclosure's exterior inspection includes actions to manage the risk of pressure release and loss of cryogenic inventory from ASU coldbox located pressure equipment. Guidance on ASU coldbox design, operation, and inspection is given in AIGA 079, *Safe Design and Operation of Cryogenic Enclosures* [1].

References

Unless otherwise specified, the latest edition shall apply.

[1] AIGA 079, *Safe Design and Operation of Cryogenic Enclosures*, Asia Industrial Gases Association, www.asiaiga.org

[2] CGA P-8.8, *Safe Design and Operation of Cryogenic Enclosures*, Compressed Gas Association, Inc. www.cganet.com

[3] AIGA 035, *Safe operation of reboilers/condensers in air separation unit*, Asia Industrial Gases Association,

www.asiaiga.org

Disclaimer

All technical publications of AIGA or under AIGA's name, including Codes of practice, Safety procedures and any other technical information contained in such publications were obtained from sources believed to be reliable and are based on technical information and experience currently available from of AIGA and others at the date of their issuance.

Where AIGA recommends reference to or use of its publications by its members, such reference to or sue of AIGA's publications by its members or third parties are purely voluntary and not binding.

Therefore, AIGA or its members make no guarantee of the results and assume no liability or responsibility in connection with the reference to or use of information or suggestions contained in AIGA's publications.

AIGA has no control whatsoever as regards, performance or non-performance, misinterpretation, proper or improper use of any information or suggestions contain in AIGA's publications by any person or entity (including AIGA members) and AIGA expressly disclaims any liability in connection thereto.

AIGA's publications are subject to periodic review and users are cautioned to obtain the latest edition.